WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 88689
Permit No.
Basin 103

NOTICE OF INTENT NO. 48329

1. OWNER Joe Ricci
MAILING ADDRESS 55 Ricci Rd Dayton, NV
ADDRESS AT WELL LOCATION 55 Ricci Ranch Rd Dayton, Nev 89403

2. LOCATION SE 1/4 NW 1/4 Sec. 25 T. 16 N/S R. 21 E/W Lyon County
PERMIT NO. (Issued by Water Resources) 06-101-06 (Parcel No.) Ricci Ranch (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
SAND + BOULDERS		0	15	15
SAND + GRAVEL		15	30	15
BROWN CLAY		30	37	7
SAND + GRAVEL		37	60	23
BLACK + GREY ROCK		60	92	32
BROWN + GREY CLAY		92	115	23
BROKEN BLACK + GREY ROCK		115	135	20
RED CLAY + SAND		135	141	7
RED CLAY + GRAVEL		141	160	19
BLACK + GREY BROKEN ROCK		160	220	60
BLACK + GREY, GREEN, RED, WHITE BROKEN ROCK		220	300	60

RECEIVED 03 JAN 21 PM 1:04 STATE ENGINEERS OFFICE

Date started 7-11-02, 20
Date completed 7-16-02, 20

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
100+		2

8. WELL CONSTRUCTION
Depth Drilled 300 Feet Depth Cased 300 Feet

HOLE DIAMETER (BIT SIZE)
9 7/8 Inches From 0 Feet To 300 Feet
Inches Feet Feet
Inches Feet Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8		.188	0	300

Perforations:
Type perforation FACTORY
Size perforation
From 240 feet to 300 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 100
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout
Gravel Packed: ☒ Yes ☐ No
From 300 feet to 100 feet

9. WATER LEVEL
Static water level 12 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature Cold °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Nevada Pump & Drilling (Contractor)
Address P.O. Box 2227 Dayton, NV 89403 (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 46357
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2187
Signed Thomas Evans (By driller performing actual drilling on site or contractor)
Date 7-24-02

(Rev. 12-01) USE ADDITIONAL SHEETS IF NECESSARY (0)-627