WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Q8-4

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 88694
Permit No.
Basin 065

NOTICE OF INTENT NO. 51120

1. OWNER Newmont Mining
MAILING ADDRESS PO Box 388
Valmy, Nv. 89438
ADDRESS AT WELL LOCATION Lone Tree Mine

2. LOCATION SW ¼ NW ¼ Sec. 23 T. 34 N/S R. 42 E. Humbolt County
PERMIT NO. (Issued by Water Resources) Parcel No. Subdivision Name

3. WORK PERFORMED
☑ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☑ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☑ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
dump material	none	0	149	149
Top soil (original ground level)		149	152	3

8. WELL CONSTRUCTION
Depth Drilled 152 Feet Depth Cased 149 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
6 Inches	0 Feet	152 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2		Sch. 80	+4	149

Perforations:
Type perforation Slot
Size perforation .020
From 139 feet to 149 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal
Placement Method: ☐ Pumped ☑ Poured
Seal Type: ☑ Neat Cement ☐ Cement Grout ☐ Concrete Grout
Gravel Packed: ☑ Yes ☐ No
From 10 feet to 150 feet

9. WATER LEVEL
Static water level none feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Eklund Drilling Co (Contractor)
Address PO Box 2748 (Contractor)
Elko Nv 89803
Nevada contractor's license number issued by the State Contractor's Board 0030823
Nevada driller's license number issued by the Division of Water Resources, the on-site driller M 1880
Signed (By driller performing actual drilling on site or contractor)
Date 1-09-03

RECEIVED
03 JAN 16 AM 11:18
STATE ENGINEERS OFFICE

Date started 12-13-, 2002
Date completed 12-14-, 2002

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
no	water		

USE ADDITIONAL SHEETS IF NECESSARY

(Rev. 12-01) (O)-627