WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 88717
Permit No.
Basin 207

NOTICE OF INTENT NO. 43191

1. OWNER Micah Criffin
MAILING ADDRESS Po Box 98 Lund NV 89317
ADDRESS AT WELL LOCATION 150 S 220 E

2. LOCATION NE ¼ SE ¼ Sec. 33 T. 12 N/S R. 62 E. White Pine County
PERMIT NO. N/A (Issued by Water Resources) 006-029-05 (Parcel No.) Lund town survey (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☒ Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top Soil		0	1	
Hard lime clay gravel		1	15	
clay gravel		15	40	
Lime stone		40	50	
clay gravel		50	67	
Lime stone	water	67	68	
clay gravel Conglomerate		68	84	
Lime stone		84	87	
clay gravel		87	115	
Lime stone	water	115	117	
clay gravel con.		117	148	
Lime stone		148	149	
clay gravel con		149	173	
Lime stone	water	173	174	
Blue clay		174	200	

RECEIVED 03 JAN -6 AM 11:21 STATE ENGINEERS OFFICE

Date started ....., 19....
Date completed Dec 26, 2002

7. WELL TEST DATA
TEST METHOD: ☒ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
20	116'	

8. WELL CONSTRUCTION
Depth Drilled 200 Feet Depth Cased 200 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
10 Inches		0 Feet	50 Feet
8 Inches		50 Feet	200 Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.9	.188	1	200

Perforations:
Type perforation mill
Size perforation 6 x 2.5" x 6 row
From 74 feet to 95 feet
From 116 feet to 137 feet
From 158 feet to 179 feet
From ..... feet to ..... feet
From ..... feet to ..... feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout
Gravel Packed: ☒ Yes ☐ No
From 50 feet to 200 feet

9. WATER LEVEL
Static water level 44 feet below land surface
Artesian flow ..... G.P.M. ..... P.S.I.
Water temperature warm °F Quality good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Orvan Maynard (Contractor)
Address Po Box 64 Lund NV 89317 (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 47226
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1556
Signed Orvan Maynard (By driller performing actual drilling on site or contractor)
Date 1-2-03

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627