

STATE OF NEVADA  
 DIVISION OF WATER RESOURCES

OFFICE USE ONLY  
 Log No. 88730  
 Permit No. \_\_\_\_\_  
 Basin 101

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. **50164**

PRINT OR TYPE ONLY  
 NOT WRITE ON BACK

1. OWNER **Frank Woolsey** ADDRESS AT WELL LOCATION **1364 Robin Drive,**  
 MAILING ADDRESS **2161 W Williams Avenue PMB 280** **Fallon, NV 89406**  
 2. LOCATION NW 1/4 SE 1/4 Sec. 21 T 19N N/S R 28E E Churchill County  
 PERMIT NO. not assigned Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Brown Sand		0	13	13
brown Clay		13	19	6
Brown sand		19	37	18
Brown Clay		37	39	2
Green Silt		39	43	4
Gray Sand		43	57	14
Gray Silt		57	64	7
Brown Clay		64	66	2
Brown Sand	XX	66	75	9

8. WELL CONSTRUCTION  
 Depth Drilled 75 Feet Depth Cased 75 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From 10 Inches To 0 Feet  
75 Feet  
 From 0 Feet To 75 Feet  
75 Feet  
 From 0 Feet To 75 Feet  
75 Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.92	.188	0	15
6 PVC	3.92	.358	15	75

Perforations:  
 Type perforation **Saw Cut**  
 Size perforation 1/8  
 From 72 feet to 75 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 70  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
 Gravel Packed:  Yes  No  
 From 70 feet to 75 feet

9. WATER LEVEL  
 Static water level 15 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature cool °F Quality unknown

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name **Parsons Drilling, Inc.** Contractor  
 Address **P.O. Box 1265** Contractor  
**Fallon Nv. 89407-1265**  
 Nevada contractor's license number issued by the State Contractor's Board **29064**  
 Nevada driller's license number issued by the Division of Water Resources / the on-site driller **1753**  
 Signed Wayne Parsons  
 By driller performing actual drilling on-site or contractor  
 Date **12/16/2002**

Date started 12/13/2002 19  
 Date completed 12/13/2002 19

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>25</u>		<u>1hr</u>

RECEIVED  
 02 DEC 24 AM 10:38  
 STATE ENGINEERS OFFICE