

STATE OF NEVADA  
 DIVISION OF WATER RESOURCES  
**WELL DRILLER'S REPORT**

OFFICE USE ONLY  
 88744  
 Permit No. 045  
 Bas

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 45497

OWNER MIKEL LEE ADDRESS AT WELL LOCATION 334 TWO BOTTLE BAR RD  
 MAILING ADDRESS 170-15 ROCKING CHAIR RD SPRING CREEK, NV 89815  
 2. LOCATION NW 1/4 NW 1/4 Sec. 36 T 33 R 57 E County EIKO  
 PERMIT NO. 023-015-003 Subdivision Name PLEASANT VALLEY  
 Issued by Water Resources Parcel No.

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
LOAM		0	2	2
CLAY		2	28	
BOULDERS		28	36	
COBBLE SAND		36	120	
CLAY		120	127	
COBBLE SAND		127	154	
CLAY	X	154	155	1
		155	180	

8. WELL CONSTRUCTION  
 Depth Drilled 180 Feet Depth Cased 180 Feet

HOLE DIAMETER (BIT SIZE)  
 From 10 Inches To 180 Feet  
 From 0 Feet To 180 Feet  
 From 0 Feet To 180 Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6</u>	<u>12.92</u>	<u>188</u>	<u>+1</u>	<u>180</u>

Perforations:  
 Type perforation MILL SLOT  
 Size perforation 3/16" X 3"  
 From 160 feet to 180 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 55  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout

Gravel Packed:  Yes  No  
 From 55 feet to 180 feet

9. WATER LEVEL  
 Static water level 90 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature COLD °F Quality \_\_\_\_\_

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name SHAREL C. FERTIG SR dba FERTIG DRILLING Contractor  
 Address P.O. Box 525 Contractor  
EIKO, NV 89803  
 Nevada contractor's license number issued by the State Contractor's Board 0031904  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1584  
 Signed Sharel C. Fertig  
 By driller performing actual drilling on site or contractor  
 Date 12-20-02

Date started 11-18-02, 19\_\_\_\_  
 Date completed 11-22-02, 19\_\_\_\_

7. WELL TEST DATA

TEST METHOD:	<input type="checkbox"/> Bailer	<input type="checkbox"/> Pump	<input type="checkbox"/> Air Lift
G.P.M.	Draw Down (Feet Below Static)	Time (Hours)	
<u>APPROX 35</u>		<u>12</u>	

RECEIVED  
 02 DEC 23 PM 1:17  
 STATE ENGINEERS OFFICE