

OFFICE USE ONLY
 License No. 88758
 Permit No. _____
 Basin 107

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT
 Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO 46035

1. OWNER NU Dept of Environmental Protection ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS 333 W Nye Lane Carson City NV 89706 Smith Valley Land Fill Smith Valley NV
 2. LOCATION SW 1/4 SW 1/4 Sec 5 T 11 N S R 24 E Lyon County _____
 PERMIT NO. _____ Issued by Water Resources Parcel No. _____ Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Abandon well				
Cement		0	20	
Bentonite Chips		20	63	
Backfill 63'-20'				
Bentonite chips				
Cement top 20'				
Remove vault + bumper posts				

8. WELL CONSTRUCTION

Depth Drilled _____ Feet Depth Cased _____ Feet

HOLE DIAMETER (BIT SIZE)
 From _____ To _____
 Inches _____ Feet _____
 Inches _____ Feet _____
 Inches _____ Feet _____

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
4"				

Perforations:
 Type perforation Factory
 Size perforation 0.20

From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout

Depth of Seal _____
 Placement Method: Pumped Poured
 Poured

Gravel Packed: Yes No
 From _____ feet to _____ feet

RECEIVED
 02 DEC 16 AM 9:23
 STATE ENGINEERS OFFICE

Date started 12-11, 2002
 Date completed 12-11, 2002

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

9. WATER LEVEL
 Static water level 53 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Boart Langyear Contractor
 Address P.O. Box 1000 Dayton NV 89403 Contractor
 Nevada contractor's license number issued by the State Contractor's Board 0010157
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller M-2222
 Signed Bruce Anderson By driller performing actual drilling on site or contractor
 Date 12-12-02