

OFFICE USE ONLY
 Log No. 88762
 Permit No. 087

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT
 Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 46034

1. OWNER Lithia Real Estate ADDRESS AT WELL LOCATION
 MAILING ADDRESS 360 E Jackson St 40 Victorian Avenue
Medford Or 97501 Sparks NV
 2. LOCATION SE 1/4 SW 1/4 Sec 4 T. 19 S R. 20 E Washoe County
 PERMIT NO. 33-316-03 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other None

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Sandy Gravel (Fill)		0	5	5
Gravelly sandy clay		5	10	5
Brown sandy clay moist		10	15	5
Gray sand/clay/gravel wet	14	15	25	10
Gravelly sand		25	30	5

8. WELL CONSTRUCTION
 Depth Drilled 30 Feet Depth Cased 30 Feet
 HOLE DIAMETER (BIT SIZE)
 From 6" Inches To 30 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet
 CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>2"</u>		<u>Sch 40</u>	<u>0</u>	<u>10</u>

 Perforations:
 Type perforation Factory
 Size perforation .020
 From 10 feet to 30 feet
 From _____ feet to _____ feet
 Surface Seal: Yes No Seal Type:
 Depth of Seal 8 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 8 feet to 30 feet

RECEIVED
 02 DEC 16 AM 9:28
 STATE ENGINEERS OFFICE

Date started 12-4, 2002
 Date completed 12-4, 2002

7. WELL TEST DATA

TEST METHOD:	Bailer		Pump		Air Lift	
	G.P.M.	Draw Down (Feet Below Static)	G.P.M.	Draw Down (Feet Below Static)	G.P.M.	Draw Down (Feet Below Static)

9. WATER LEVEL
 Static water level 14' feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Boart Longuear Contractor
 Address 32 Stokes Dr Contractor
Dayton NV 89403
 Nevada contractor's license number issued by the State Contractor's Board 00219716
 Nevada driller's license number issued by the Division of Water Resources the on-site driller M 2222
 Signed Bruce Anderson
 By driller performing actual drilling on site or contractor
 Date 12-12-02