

STATE OF NEVADA
 DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
 Log No. 88779
 Permit No. _____
 Basin Ø87
 NOTICE OF INTENT NO. 45825

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.348

1. OWNER Washoe County DWR ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS 1938 Reno, NV 1875 Wendell Ave
Reno, NV Reno, NV
 2. LOCATION Sec 13 T. 19 N. R. 19 E. Washoe County
 PERMIT NO. Ø30010 Issued by Water Resources Parcel No. _____ Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>Reed Base</u>		<u>0</u>	<u>2</u>	<u>2</u>
<u>Silty Sand</u>	<u>Yes</u>	<u>2</u>	<u>12</u>	<u>10</u>
<u>Elemental Gravel</u>		<u>12</u>	<u>16</u>	<u>4</u>
<u>Coarse sand & pebbles</u>	<u>Yes</u>	<u>16</u>	<u>19</u>	<u>3</u>
<u>Clay</u>		<u>19</u>	<u>20</u>	<u>1</u>
<u>Sand</u>	<u>Yes</u>	<u>20</u>	<u>22</u>	<u>2</u>
<u>Silty</u>		<u>22</u>	<u>30</u>	<u>8</u>
<u>Base is filled with bentonite from 22 to 30</u>				

8. WELL CONSTRUCTION
 Depth Drilled 30 Feet Depth Cased 22 Feet
 HOLE DIAMETER (BIT SIZE)
 From 6 Inches To 30 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet
 CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>2</u>		<u>3/4</u>	<u>0</u>	<u>22</u>

 Perforations:
 Type perforation Slotted
 Size perforation 1/2"
 From 12 feet to 22 feet
 From _____ feet to _____ feet
 Surface Seal: Yes No Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout
 Placement Method: Pumped Poured
 Gravel Packed: Yes No
 From 10 feet to 22 feet

Date started 3/15
 Date completed 3/15

7. WELL TEST DATA

TEST METHOD: <input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			
G.P.M.	Draw Down (Feet Below Static)	Time (Hours)	

9. WATER LEVEL
 Static water level 16 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____
 10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Personic Corp Contractor
 Address 305 E Comstock Contractor
Chandler AZ
 Nevada contractor's license number issued by the State Contractor's Board 0081965
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1677
 Signed J. J. W. Smith
 By driller performing actual drilling on site or contractor
 Date 3/15/03