

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

Log No. 88183
 Permit No. 087
 Basin
 NOTICE OF INTENT NO. 45516

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

1. OWNER Washoe County 2013 ADDRESS AT WELL LOCATION 227 E 1950th St Reno NV
 MAILING ADDRESS 4930 E 17th Hwy Reno NV
 2. LOCATION N 1/4 Sec 13 T 19 R 19 E Washoe County
 PERMIT NO. 642030010 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thick-ness |
|------------------------|--------------|------|----|------------|
| Gravel Fill | | 0 | 1 | 1 |
| Small Gravel & Cobbles | | 1 | 8 | 7 |
| TC 8" | | | | |
| Strat + Small Gravel | | 8 | 18 | 10 |
| Gravel + 8" cobbles | Yes | 18 | 32 | 14 |
| Clay + Cobbles | | 32 | 37 | 5 |
| Sand + Clay | | 37 | 38 | 1 |
| Clay + Cobbles - Small | | 38 | 55 | 17 |
| And Gravel | | | | |

8. WELL CONSTRUCTION
 Depth Drilled 55 Feet Depth Cased 55 Feet
 HOLE DIAMETER (BIT SIZE)
 From 0 To 55
6 Inches 0 Feet 55 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet
 CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|--------------------|---------------------|-------------------------|-------------|-----------|
| 2 | | Sch 40 DW | | |

 Perforations:
 Type perforation slotted
 Size perforation 1/2"
 From 30 feet to 55 feet
 From _____ feet to _____ feet
 Surface Seal: Yes No Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout
 Depth of Seal 28
 Placement Method: Pumped Poured
 Gravel Packed: Yes No
 From 28 feet to 55 feet

9. WATER LEVEL
 Static water level 40 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Pisonic Corp Contractor
 Address 305 E Comstock Contractor
Chandler AZ
 Nevada contractor's license number issued by the State Contractor's Board 0051765
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1677
 Signed J.P. Dunlap
 By driller performing actual drilling on site or contractor
 Date 3/12/03

Date started 3/12 2003
 Date completed 3/12 2003

7. WELL TEST DATA

| TEST METHOD: <input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift | | | |
|--|-------------------------------|--------------|--|
| G.P.M. | Draw Down (Feet Below Static) | Time (Hours) | |
| | | | |
| | | | |
| | | | |