

OFFICE USE ONLY  
 Log No. 08792  
 Permit No. 087  
 Basin 087

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

**WELL DRILLER'S REPORT**  
 Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 48519

1. OWNER Washoe County DWIR ADDRESS AT WELL LOCATION 1401 Wells Ave Reno Nev  
 MAILING ADDRESS 4930 Energy Way Reno Nev

2. LOCATION NW 1/4 NW 1/4 Sec 13 T 19 N R 19 E Washoe County  
 PERMIT NO. W 030040 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other Sanic

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>ROAD BRSE</u>		<u>0</u>	<u>2</u>	<u>2</u>
<u>CLAY</u>		<u>2</u>	<u>4</u>	<u>2</u>
<u>SILT &amp; GRAVEL</u>		<u>4</u>	<u>6</u>	<u>2</u>
<u>SANDY SILT &amp; GRAVEL</u>		<u>6</u>	<u>9</u>	<u>3</u>
<u>CLAY</u>		<u>9</u>	<u>9 1/2</u>	<u>1/2</u>
<u>SANDY SILT GRAVEL &amp; Cobbles TO 8"</u>			<u>28 1/2</u>	<u>19</u>
<u>CLAY &amp; Cobbles</u>		<u>28 1/2</u>	<u>31</u>	<u>2 1/2</u>
<u>SANDY SILT &amp; GRAVEL AND Cobbles TO 6"</u>		<u>31</u>	<u>50</u>	<u>19</u>
<u>SAND GRAVEL Cobbles</u>	<u>yes</u>	<u>50</u>	<u>51</u>	<u>1</u>
<u>SILT SAND GRAVEL</u>		<u>51</u>	<u>56</u>	<u>5</u>

8. WELL CONSTRUCTION  
 Depth Drilled 56 Feet Depth Cased 56 Feet

HOLE DIAMETER (BIT SIZE)  
 From 6 Inches To 0 Feet 56 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>2</u>		<u>SC40 PVC</u>		

Perforations:  
 Type perforation Slotted  
 Size perforation 1.020  
 From 31 feet to 56 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 29  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout

Gravel Packed:  Yes  No  
 From 29 feet to 56 feet

9. WATER LEVEL  
 Static water level 29 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature \_\_\_\_\_ °F Quality \_\_\_\_\_

Date started 3/31, 2023  
 Date completed 3/22, 2023

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Prosonic Corp Contractor  
 Address 305 E Comstock Contractor  
Chandler AZ

Nevada contractor's license number issued by the State Contractor's Board 0051765  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1677

Signed JJ Campbell By driller performing actual drilling on site or contractor  
 Date 3/22/23