

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 48823

1. OWNER Washoe County DWR ADDRESS AT WELL LOCATION 590 Sunshine Lane Reno Nev  
 MAILING ADDRESS 4930 Energy Way Reno Nev

2. LOCATION SW 1/4 SW 1/4 Sec. 7 T. 19 N. S. R. 20 E Washoe County  
 PERMIT NO. WLO88040 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  Domestic  Irrigation  Test  
 Deepen  Abandon  Other  Municipal/Industrial  Monitor  Stock  Cable  Rotary  RVC  
 Air  Other Seismic

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Road Base		0	2	2
Clay		2	4	2
Sand silt gravel + Cobbles To 4"		4	10	6
Sand silt gravel and Cobbles To 5"		10	13	3
Sand + Gravel		13	14	1
Sand + Cobbles To 4"		14	16	2
Silt Sand Gravel and Cobbles To 10"		14	26	10
Silty sand		26	31	5
Cobbles To 5"		31	33	2
Clay + Cobbles		33	36	3
Cobbles		36	38	2
Clay + Cobbles		38	42	5
Sand	Yes	42	44	2
Silt + Gravel		44	56	12

8. WELL CONSTRUCTION  
 Depth Drilled 56 Feet Depth Cased 56 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From 6 Inches To 56 Feet  
 From 0 Feet To 56 Feet  
 From 0 Feet To 56 Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>2</u>		<u>Sch 40 PVC</u>	<u>0</u>	<u>56</u>

Perforations:  
 Type perforation Slotted  
 Size perforation .020  
 From 36 feet to 56 feet  
 From 0 feet to 56 feet  
 From 0 feet to 56 feet  
 From 0 feet to 56 feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 34  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
 Gravel Packed:  Yes  No  
 From 34 feet to 56 feet

9. WATER LEVEL  
 Static water level 40 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature \_\_\_\_\_ °F Quality \_\_\_\_\_

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Prosonic Corp Contractor  
 Address 305 E Comstock Chandler AZ  
 Nevada contractor's license number issued by the State Contractor's Board 0051765  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1677  
 Signed J. J. Donley  
 By driller performing actual drilling on site or contractor  
 Date 3/26/03

Date started 3/22, 2003  
 Date completed 3/24, 2003

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			

RECEIVED  
 03 APR - 7 AM 10  
 WATER RESOURCES OFFICE