WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 88805
Permit No.
Basin 102

NOTICE OF INTENT NO. 50157

1. OWNER Carl Johnson
MAILING ADDRESS 1650 Grouse Lane
Silver Springs, NV 89406

ADDRESS AT WELL LOCATION 1650 Grouse Lane,
Fallon,NV 89406

2. LOCATION NW 1/4 SE 1/4 Sec. 30 T 17N N/S R 25E E Churchill County
PERMIT NO. Issued by Water Resources
17-553-06 Parcel No.
Subdivision Name

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[ ] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Brown Sand		0	70	70
Gray Silt		70	81	11
Brown sand		81	83	2
Gray Sand		83	116	33
Brown Clay		116	119	3
Brown Sand	XX	119	130	11

RECEIVED
02 DEC 19 AM 11:10
STATE ENGINEERS OFFICE

Date started 11/12/2002 , 19__
Date completed 11/12/2002 , 19__

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
25		1hr

8. WELL CONSTRUCTION
Depth Drilled 130 Feet Depth Cased 130 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
10	Inches	0	Feet	130	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.92	.188	0	10
6 PVC	3.92	.258	10	130

Perforations:
Type perforation Saw Cut
Size perforation 1/8
From 121 feet to 130 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 50
Placement Method: [X] Pumped [ ] Poured
Seal Type: [ ] Neat Cement [X] Cement Grout [ ] Concrete Grout
Gravel Packed: [X] Yes [ ] No
From 50 feet to 130 feet

9. WATER LEVEL
Static water level 40 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature cool °F Quality unknown

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Parsons Drilling, Inc. Contractor
Address P.O. Box 1265 Contractor
Fallon Nv. 89407-1265
Nevada contractor's license number issued by the State Contractor's Board 29064
Nevada driller's license number issued by the Division of Water Resources, the ~~on-site~~ driller 1753
Signed W Wayne Parsons
By driller performing actual drilling ~~on-site~~ or contractor
Date 12/02/2002

USE ADDITIONAL SHEETS IF NECESSARY