WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.34

OFFICE USE ONLY
Log No. 88845
Permit No.
Basin Ø87

NOTICE OF INTENT NO. 46044

1. OWNER City of Reno Pub. Works Dept
MAILING ADDRESS 244 Keystone Ave
Reno, NV 89503
ADDRESS AT WELL LOCATION North side of Arlington Ave

2. LOCATION NW 1/4 SE 1/4 Sec. 17 T 19 N/S R 19 E WASHOE County
PERMIT NO. | Issued by Water Resources | Parcel No. | Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☒ Other Sonic

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
0-17 SAND		0	17	
gravel		17	21	
cobble x gravel		21	29	
sand, silt, gravel		29	35	

8. WELL CONSTRUCTION
Depth Drilled 35 Feet Depth Cased 35 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
6" Inches	0 Feet	35 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2"	sch 40		0	25

Perforations:
Type perforation factory
Size perforation .020
From 25 feet to 35 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 5
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout
Gravel Packed: ☒ Yes ☐ No
From 35 feet to 23 feet

9. WATER LEVEL
Static water level 32 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Brent Longyear
Contractor
Address Box 1005
Contractor
Dayton, NV 89403
Nevada contractor's license number issued by the State Contractor's Board 0010157
Nevada driller's license number issued by the Division of Water Resources, the on-site driller WW 2198
Signed
By driller performing actual drilling on site or contractor
Date 3/28/03

Date started 3-21-03, 20
Date completed 3-21-03, 20

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

RECEIVED 2003 APR 14 PM 1:30 DIVISION OF WATER RESOURCES

(Rev. 12-01)

USE ADDITIONAL SHEETS IF NECESSARY

(O)-627