



Permit No. 88348
 Basin 087

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 46043

1. OWNER City of Reno Dept. of Pub Works ADDRESS AT WELL LOCATION South Side of Reelston Ave
 MAILING ADDRESS 267 REELSTON AVE
RENO, NV 89503

2. LOCATION SW 1/4 NE 1/4 Sec 11 T 19 N R 19 E Washoe County

PERMIT NO. Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC-
 Air Other SOPIC

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thick-ness |
|-----------------|--------------|------|----|------------|
| 0-13 silty sand | | 0 | 13 | |
| cobbles | | 13 | 19 | |
| GRAVELS | | 19 | 22 | |
| sand cobbles | | 22 | 31 | |
| silty clay | | 31 | 35 | |

8. WELL CONSTRUCTION
 Depth Drilled 35 Feet Depth Cased 35 Feet
 HOLE DIAMETER (BIT SIZE)
6" From 0 Feet To 35 Feet
 Inches Feet Feet
 Inches Feet Feet
 Inches Feet Feet

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|--------------------|---------------------|-------------------------|-------------|-----------|
| <u>2"</u> | <u>sch. 40</u> | | <u>0</u> | <u>25</u> |

Perforations:
 Type perforation g20
 Size perforation factory
 From 35 feet to 25 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 5 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 35 feet to 23 feet

9. WATER LEVEL
 Static water level 31 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Barret Longyear Contractor
 Address P.O. Box 1000 Contractor
Dayton, NV 89403
 Nevada contractor's license number 0010157
 issued by the State Contractor's Board.
 Nevada driller's license number issued by the M-2198
 Division of Water Resources, the on-site driller
 Signed [Signature]
 By driller performing actual drilling on site or contractor
 Date 3/28/03

Date started 3-20-03, 20____
 Date completed 3-20-03, 20____

7. WELL TEST DATA

| TEST METHOD: | G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|---|--------|-------------------------------|--------------|
| <input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift | | | |

RECEIVED
 13 APR -4 PM 1:30
 STATE ENGINEERS OFFICE