WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 88856
Permit No.
Basin Ø87

NOTICE OF INTENT NO. 46041

1. OWNER VISTA CANYON Group
MAILING ADDRESS PO Box 281324
LAKEWOOD, CO. 80228-8304

ADDRESS AT WELL LOCATION
495 E. NUGGET AVE. SPARKS, NV.

2. LOCATION NE ¼ NE ¼ Sec. 9 T. 19 N/S R. 20 E. MDB+M Washoe County

PERMIT NO. NDEP CU91-546 (Issued by Water Resources) | 34-102-13 (Parcel No.) | Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other ROTA Sonic

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
SAND GRAVEL Br	15	0'	15'	
SAND Grey		15	50'	

8. WELL CONSTRUCTION
Depth Drilled 50' Feet Depth Cased 50' Feet

HOLE DIAMETER (BIT SIZE)

		From	To
8"	Inches	0' Feet	50' Feet
	Inches	Feet	Feet
	Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2"	5.5		0'	48'

Perforations:
Type perforation FACTORY
Size perforation .040
From 48' feet to 50' feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 44'
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50' feet to 46' feet

9. WATER LEVEL
Static water level 13' feet below land surface
Artesian flow NO G.P.M. P.S.I.
Water temperature COLD °F Quality

Date started 4-15, 19 03
Date completed 4-15, 19 03

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name BART LONGYEAR (Contractor)
Address 32 STOKES DR MOUND house, NV. (Contractor)

Nevada contractor's license number issued by the State Contractor's Board 0010157
Nevada driller's license number issued by the Division of Water Resources, the on-site driller M-12071
Signed Dennis R Reed (By driller performing actual drilling on site or contractor)
Date 4-15-03

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627