WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 88866
Permit No. 62829T
Basin 061

NOTICE OF INTENT NO. 50829

1. OWNER Barrick Goldstrike Mines VD97-11
MAILING ADDRESS P.O. Box 29
Elko, NV 89803

ADDRESS AT WELL LOCATION Barrick Goldstrike minesite, north of Carlin, NV.

2. LOCATION SE 1/4 NE 1/4 Sec. 19 T 36N N/S R 50E E Eureka County
PERMIT NO. 62829-T (Issued by Water Resources) | N/A (Parcel No.) | N/A (Subdivision Name)

3. **WORK PERFORMED**
☐ New Well ☐ Replace ☐ Recondition
☐ Deepen ☒ Abandon ☐ Other

4. **PROPOSED USE**
☐ Domestic ☐ Irrigation ☐ Test
☒ Municipal/Industrial ☐ Monitor ☐ Stock

5. **WELL TYPE**
☐ Cable ☐ Rotary ☒ RVC
☐ Air ☐ Other

6. **LITHOLOGIC LOG**

Material	Water Strata	From	To	Thickness
Abandoned by pumping abantonite via tremie from T.D. to 357', then poured hole plug and abantonite to 20' and capped with neat cement.				
Quantities Used:				
Cement: 5.9 cu.ft.				
Hole plug: 67.5 cu.ft.				
Abantonite: 213.9 cu.ft.				

Date started 1/11/2003, 19__
Date completed 1/11/2003, 19__

7. **WELL TEST DATA**
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. **WELL CONSTRUCTION**
Depth Drilled 760 Feet Depth Cased 740 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
17.5	Inches	0	Feet	40	Feet
9.875	Inches	40	Feet	760	Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
12.75	33.38	0.250	0	40
6.625	17.02	0.250	+1	740

Perforations:
Type perforation Louver
Size perforation 0.125"
From 100 feet to 740 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 100'
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 100 feet to 760 feet

9. **WATER LEVEL**
Static water level 698 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. **DRILLER'S CERTIFICATION**
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Lang Exploratory Drilling (Contractor)
Address P.O. Box 5279 (Contractor)
Elko, NV 89802-5279
Nevada contractor's license number issued by the State Contractor's Board 0021976
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1716
Signed David Haas (By driller performing actual drilling on-site or contractor)
Date 1/16/03

USE ADDITIONAL SHEETS IF NECESSARY

RECEIVED JAN 21 PM 1:03 WATER ENGINEERS OFFICE

BSTL