WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

# WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 88875
Permit No.
Basin 087

NOTICE OF INTENT NO. 22649

1. OWNER K. G. Walters
MAILING ADDRESS 1027 S. Loch Haven Dr. Santa Rosa, CA
ADDRESS AT WELL LOCATION 8500 Mira Loma Road, Reno NV

2. LOCATION NE ¼ NW ¼ Sec. 4 T. 18 N/S R. 20 E. Washoe County
PERMIT NO. DEW-28 (Issued by Water Resources) 022-220-04 (Parcel No.) Subdivision Name

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☐ Deepen ☒ Abandon ☐ Other

4. PROPOSED USE Temp Dewatering
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other Bucket Auger

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| Abandoned 18 wells. | | | | |
| Pulled well Casing | | | | |
| Removed Gravel Pack down to 20' | | | | |
| Poured Concrete Grout in hole to the top of Ground. | | | | |

RECEIVED 02 AUG 28 PM 2:10 STATE ENGINEER'S OFFICE

Date started 8-27-02, 20
Date completed 8-27-02, 20

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

| G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|---|---|---|
| | | |

8. WELL CONSTRUCTION
Depth Drilled 45' Feet Depth Cased 45' Feet

HOLE DIAMETER (BIT SIZE)

| | From | To |
|---|---|---|
| 24" Inches | 0 Feet | 45' Feet |
| Inches | Feet | Feet |
| Inches | Feet | Feet |

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|---|---|---|---|---|
| 8" | PVC | Sch-40 | 0 | 45' |
| | | | | |
| | | | | |

Perforations:
Type perforation
Size perforation
From feet to feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 20'
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout

Gravel Packed: ☐ Yes ☐ No
From feet to feet

9. WATER LEVEL
Static water level 20' feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Griffin Dewatering (Contractor)
Address 536 E. Maitland St. (Contractor)
Ontario, CA 91761
Nevada contractor's license number issued by the State Contractor's Board 0031246
Nevada driller's license number issued by the Division of Water Resources, the on-site driller M-1985
Signed (By driller performing actual drilling on site or contractor)
Date 8-27-02

(Rev. 12-01) USE ADDITIONAL SHEETS IF NECESSARY (O)-627