

STATE OF NEVADA
 DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
 Log No. 88908
 Permit No. 63987
 Basin 061

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. **50822**

1. OWNER **Newmont Mining Corporation HDDW-7**
 MAILING ADDRESS **P.O. Box 669 Carlin, NV 89822**

ADDRESS AT WELL LOCATION **Leeville minesite, about 19 miles NW of Carlin, NV.**

2. LOCATION **SW 1/4 SW 1/4 Sec. 2 T 35N**
 PERMIT NO. **63987**
Issued by Water Resources

N/S R **50E E** County **Eureka**
 Parcel No. **N/A** Subdivision Name **N/A**

3. WORK PERFORMED
 New Well
 Replace
 Recondition
 Deepen
 Abandon
 Other

4. PROPOSED USE
 Domestic
 Municipal/Industrial
 Irrigation
 Monitor
 Test
 Stock

5. WELL TYPE
 Cable
 Rotary
 RVC
 Air
 Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Brown siltstone		0	155	155
Gray clay and siltstone		155		
Gray siltstone		175	280	105
Gray mudstone		280	425	145
Gray mudstone with clay		425	475	50
Gray mudstone with occasional clay zones		475	800	325
Hornfels and siltstone		800	880	80
Gray silty limestone		880	1055	175
Gray silty mudstone		1055	1450	395
Dark gray limestone		1450	1565	115
Intrusive		1565	1595	30
Micrite		1595	1645	50
Silty micrite		1645	1700	55
Silty limestone		1700	2510	810

Construction Detail:

Description	From	To	Thickness
40" casing cemented	0	35	35
34" casing cemented	0	1261	1261
24" casing cemented	0	156	156

Louwer casing above 1504' is "leaky pipe".

Date started **10/23/2002**
 Date completed **12/3/2002**

7. WELL TEST DATA

TEST METHOD: Bailor Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
512	1	1

8. WELL CONSTRUCTION

Depth Drilled **2500** Feet Depth Cased **2505** Feet

HOLE DIAMETER (BIT SIZE)

Inches	From	To	Feet
46	0	35	Feet
38	35	1255	Feet
31	1255	2510	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
40	210.9	0.500	0	35
34	178.9	0.500	0	1261
24	94.62	0.375	0	2505

Perforations:
 Type perforation **Louwer**
 Size perforation **0.125"**

From	To	Feet
404	424	feet
744	764	feet
1084	1104	feet
1504	2505	feet

Surface Seal: Yes No
 Depth of Seal **156'**
 Placement Method: Pumped Poured
 Seal Type: Neat Cement Cement Grout Concrete Grout
 Gravel Packed: Yes No
 From **156** feet to **2510** feet

9. WATER LEVEL

Static water level **1257.9** feet below land surface
 Artesian flow **N/A** G.P.M. _____ P.S.I. _____
 Water temperature **77** °F Quality **Good**

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name **Lang Exploratory Drilling** Contractor
 Address **P.O. Box 5279** Contractor

Elko, NV 89802-5279
 Nevada contractor's license number issued by the State Contractor's Board **0021976**

Nevada driller's license number issued by the Division of Water Resources, the on-site driller **2130**

Signed **Scott Belluston**
 By driller performing actual drilling on-site or contractor

Date **12/20/02**

B.S.L