

STATE OF NEVADA
 DIVISION OF WATER RESOURCES
 WELL DRILLER'S REPORT

OFFICE USE ONLY
 Log No. 88909
 Permit No. 63987
 Basin 961

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 50824-

OWNER Newmont Mining Corporation HDDW-11 ADDRESS AT WELL LOCATION Leeville minesite, north
 MAILING ADDRESS P.O. Box 669 of Carlin, NV.
Carlin, NV 89822

2. LOCATION SE 1/4 SW 1/4 Sec. 2 T 35N N/S R 50E E Eureka County
 PERMIT NO. 63987 Issued by Water Resources Parcel No. N/A Subdivision Name N/A

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other Flooded

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Gray siliceous mudstone		0	170	170
Intrusive		170	225	55
Gray siliceous mudstone		225	230	5
Intrusive and mudstone		230	240	10
Gray siliceous mudstone with occasional hornfels		240	380	140
Gray silty limestone		380	430	50
Gray siliceous mudstone		430	455	25
Gray limestone		455	495	40
Greenstone		495	500	5
Gray-brown hornfels		500	580	80
Greenstone		580	590	10
Brown glassy hornfels		590	725	135
Gray mudstone		725	750	25
Hornfels		750	835	85
Gray limestone and silty limestone		835	1135	300
Gray silty mudstone		1135	1150	15
Intrusive		1150	1185	35
Gray silty mudstone		1185	1225	40
Dark gray sandstone		1225	1260	35
Gray silty mudstone		1260	1300	40
Hole plug		100	276	176

8. WELL CONSTRUCTION
 Depth Drilled 1300 Feet Depth Cased 1295 Feet
 HOLE DIAMETER (BIT SIZE)
 From 0 Feet To 37 Feet
25 Inches 0 Feet 37 Feet
19 Inches 37 Feet 1300 Feet
 Inches Feet Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
20	52.73	0.250	0	37
12.75	33.38	0.250	+3	1295

Perforations:
 Type perforation Wire Wrap
 Size perforation 0.050"
 From 332.95 feet to 1295 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 100' Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 276 feet to 1300 feet

9. WATER LEVEL
 Static water level 342.1 feet below land surface
 Artesian flow N/A G.P.M. _____ P.S.I. _____
 Water temperature Cold °F Quality Good

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Lang Exploratory Drilling Contractor
 Address P.O. Box 5279 Contractor
Elko, NV 89802-5279

Date started 1/8/2003, 19
 Date completed 1/12/2003, 19

7. WELL TEST DATA

TEST METHOD:	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift		
G.P.M. <u>500</u>	<u>Not Meas.</u>	<u>1</u>

Nevada contractor's license number issued by the State Contractor's Board 0021976
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1995
 Signed Guadalupe Jacobo
 By driller performing actual drilling at site or contractor
 Date 1/16/03

B. STL