

STATE OF NEVADA
 DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
 Log No. 88910
 Permit No. 63987
 Basin 061

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. **50824**

1. OWNER Newmont Mining Corp. HDDW-13
 MAILING ADDRESS P.O. Box 669
Carlin, NV 89822

ADDRESS AT WELL LOCATION Leeville minesite, about
19 miles NW of Carlin, NV.

2. LOCATION SE 1/4 SW 1/4 Sec. 2 T 35N
 PERMIT NO. 63987 Issued by Water Resources
N/A Parcel No.

N/S R 50E E Eureka County
N/A Subdivision Name

3. WORK PERFORMED
 New Well
 Replace
 Recondition
 Deepen
 Abandon
 Other

4. PROPOSED USE
 Domestic
 Municipal/Industrial
 Irrigation
 Monitor
 Test
 Stock

5. WELL TYPE
 Cable
 Rotary
 RVC
 Air
 Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Gray siliceous mudstone		0	55	55
Silicified hornfels		55	120	65
No returns		120	155	35
Silicified hornfels		155	220	65
Intrusive		220	225	5
Gray silicified mudstone			275	50
Gray mudstone		275	290	15
Intrusive		290	320	30
Biotite hornfels		320	385	65
Gray siliceous mudstone		385		
Gray hornfels		400	415	15
Gray siliceous mudstone		415	440	25
Biotite hornfels		440	490	50
Intrusive		490	510	20
Hornfels		510	535	25
Gray siliceous mudstone		535	670	135
Hornfels		670	680	10
Gray siliceous mudstone		680	710	30
Hornfels		710	770	60
Intrusive		770	775	5
Biotite hornfels		775	780	5
Gray siliceous mudstone		780	830	50
Gray silty limestone		830	865	35
Hornfels		865	900	35
Intrusive		900	905	5
Gray silty limestone		905	1115	210

Continued on next page

8. WELL CONSTRUCTION
 Depth Drilled 1190 Feet Depth Cased 1190 Feet

HOLE DIAMETER (BIT SIZE)
 From: 25 Inches To: 37 Feet
19 Inches 37 Feet 1190 Feet
 Inches Feet Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
20	78.60	0.375	0	37
12.75	33.38	0.250	+3	1190

Perforations:
 Type perforation Wire Wrap
 Size perforation 0.050"

From	To
<u>449</u> feet	<u>1190</u> feet
_____ feet	_____ feet
_____ feet	_____ feet
_____ feet	_____ feet
_____ feet	_____ feet

Surface Seal: Yes No
 Depth of Seal 100'
 Placement Method: Pumped Poured
 Seal Type: Neat Cement Cement Grout Concrete Grout

Gravel Packed: Yes No
 From 310 feet to 1190 feet

Date started 12/12/2002, 19
 Date completed 12/21/2002, 19

7. WELL TEST DATA

TEST METHOD:	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift		
G.P.M. <u>195</u>	<u>Not Meas.</u>	<u>1</u>

9. WATER LEVEL
 Static water level 357 feet below land surface
 Artesian flow N/A G.P.M. _____ P.S.I.
 Water temperature Cold °F Quality Good

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Lang Exploratory Drilling Contractor
 Address P.O. Box 5279 Contractor
Elko, NV 89802-5279
 Nevada contractor's license number issued by the State Contractor's Board 0021976
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1995
 Signed Guadalupe Jacobo
 By driller performing actual drilling on-site or contractor
 Date 1/10/03

B.S.T.L

