WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT
Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 88931
Permit No.
Basin 105

NOTICE OF INTENT NO. 50609

1. OWNER West Ridge Homes Inc.
MAILING ADDRESS 1528 Hwy 395, Suite 215
Gadnerville, NV 89410

ADDRESS AT WELL LOCATION 0 Hwy.88 Parcel B-1

2. LOCATION NE 1/4 SW 1/4 Sec. 30 T 12 N/S R 20 E Douglas County
PERMIT NO. Issued by Water Resources | 19-300-44 Parcel No. | Subdivision Name

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[ ] Air [X] Other Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Brown Fine DG	No	0	31	31
Gray Fine DG	Yes	31	63	32
Brown sandy DG	Yes	63	109	46
Med. to course DG	Yes	109		
Brown			165	56

RECEIVED
02 NOV -5 AM 11:03
STATE ENGINEERS OFFICE

Date started 9/28/1902 , 19__
Date completed 10/3/2002 , 19__

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
+-55		2 Hrs

8. WELL CONSTRUCTION
Depth Drilled 165 Feet Depth Cased 165 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
12 1/2	Inches	0	Feet	165	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8 5/8	16.94	.188	+2	165

Perforations:
Type perforation Factory Milled
Size perforation 1/8 X 3 8 row
From 125 feet to 165 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 100
Placement Method: [X] Pumped [ ] Poured
Seal Type: [X] Neat Cement [ ] Cement Grout [ ] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 100 feet to 165 feet

9. WATER LEVEL
Static water level 16 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature cold °F Quality good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Eddco Exploration Inc Contractor
Address 7780 Curry Road Contractor
Fallon,NV. 89406
Nevada contractor's license number issued by the State Contractor's Board 27673A
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1586
Signed By driller performing actual drilling on-site or contractor
Date 10/13/2002

USE ADDITIONAL SHEETS IF NECESSARY