WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT
Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 88940
Permit No.
Basin Ø84

NOTICE OF INTENT NO. 46636

1. OWNER Paul Neuffer
MAILING ADDRESS 3155 Bacon Rind Road
Reno, NV 89510

ADDRESS AT WELL LOCATION 7040 Sage Canyon
Reno,Nevada 89510

2. LOCATION NW 1/4 SE 1/4 Sec. 1 T 21N N/S R 20E E Washoe County
PERMIT NO. (Issued by Water Resources) 076-281-34 (Parcel No.) (Subdivision Name)

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[X] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
D.G.		0	108	108
Hard Grey Rock		108	403	295
Broken Black Rock	x	403	435	32
T.D. 435		435		

RECEIVED
02 DEC -2 PM 12:20
STATE ENGINEERS OFFICE

Date started 11/01/2002, 19__
Date completed 11/12/2002, 19__

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
20	380	1 hour
30	400	1hour
30+	420	3 hours

8. WELL CONSTRUCTION
Depth Drilled 435 Feet Depth Cased 435 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
10-5/8	Inches	0	Feet	60	Feet
8-1/2	Inches	60	Feet	435	Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6-5/8	12.94	.188	+1-1/2	435

Perforations:
Type perforation Factory Sawed
Size perforation 3/32 x 3
From 415 feet to 435 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 50
Placement Method: [ ] Pumped [X] Poured
Seal Type: [ ] Neat Cement [ ] Cement Grout [X] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 50 feet to 435 feet

9. WATER LEVEL
Static water level 360 feet below land surface
Artesian flow G.P.M. P.S.I
Water temperature cool °F Quality good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name A.S.A.P. Pump & Well Service (Contractor)
Address P.O. Box 60130 (Contractor)
Reno,Nevada 89506
Nevada contractor's license number issued by the State Contractor's Board 0035387-B
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2121
Signed Larry Welch (By driller performing actual drilling on-site or contractor)
Date 11/25/2002

USE ADDITIONAL SHEETS IF NECESSARY