

OFFICE USE ONLY
 Log No. 88950
 Permit No. 105
 Basin. 105
 50352

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 50352

1. OWNER John DeCarlo ADDRESS AT WELL LOCATION 1031 Derby Gardnerville, NV 89410
 MAILING ADDRESS 2110 Lakeshore Dr Carson City, NV 89704

2. LOCATION S.E. 1/4 SW 1/4 Sec 24 T. 12 N. R. 20 E Douglas County
 PERMIT NO. 122024401022 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
BLACK+BROWN SAND + Boulders		0	40	40
BROWN CLAY		40	46	6
BROWN SAND + Boulders		46	80	34
BLACK, BROWN, GREY Boulders		80	100	20
SAND + BROWN CLAY		100	110	10
BROWN + BLACK SAND + BLACK + BROWN, GREEN		110	180	70
GREY BROKEN ROCK				

8. WELL CONSTRUCTION
 Depth Drilled 180 Feet Depth Cased 180 Feet

HOLE DIAMETER (BIT SIZE)
10 5/8 Inches From 0 Feet To 180 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 3/8</u>		<u>.188</u>	<u>0</u>	<u>180</u>

Perforations:
 Type perforation FACTORY
 Size perforation _____
 From 160 feet to 180 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout

Depth of Seal 50'
 Placement Method: Pumped Poured

Gravel Packed: Yes No
 From 180 feet to 50 feet

9. WATER LEVEL
 Static water level _____ feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature Cold °F Quality Good

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name NEVADA PUMP & DRILLING
 Address P.O. BOX 2227 DAYTON, NV 89403

Nevada contractor's license number issued by the State Contractor's Board 0046357
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2187

Signed Thomas Elana
 By driller performing actual drilling on site or contractor
 Date 9-1-02

Date started 8-27-02, 20
 Date completed 8-28-02, 20

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>40+</u>		<u>2</u>

RECEIVED
 02 DEC 16 AM 9:50
 STATE ENGINEERS OFFICE