Plugged under NOI 60073

WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 88981
Permit No. 65842
Basin 069

NOTICE OF INTENT NO. 44235

1. OWNER WINNEMUCCA FARMS, INC.
MAILING ADDRESS 1 POTATO PLACE
WINNEMUCCA, NV 89445

ADDRESS AT WELL LOCATION WELL # 9
GOLCONDA BUTTE
N41.069228 W117.580918 NAD27

2. LOCATION SW ¼ NW ¼ Sec. 22 T. 37 N/S R. 39 E. HUMBOLDT County

PERMIT NO. 65842, 65843 (Issued by Water Resources) | Parcel No. | Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☒ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☒ Other REVERSE

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
TOP SOIL		0	8	8
HARD BURNT CLAY		8	26	18
LT BRN CLAY		26	28	2
SAND, SM. GRAVEL		28	85	57
BRN CLAY		85	97	12
SAND, SM GRAVEL		97	117	20
BRN CLAY, IMBEDDED GRAVEL		117	126	9
SANDY CLAY		126	135	9
SAND, SM GRAVEL		135	145	10
BRN CLAY		145	162	17
FINE-COARSE SAND, SANDSTONE		162	167	5
BRN STICKY CLAY		167	175	8
FINE-COARSE SAND, FEW GRAVEL		175	186	11
RED CLAY		186	195	9
BASALT, BROKEN BASALT		195	554	359
SOME GRAVEL				

RECEIVED 03 APR 28 PM 1:23 STATE ENGINEER'S OFFICE

Date started FEBRUARY 27, 2003
Date completed MARCH 30, 2003

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☒ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
800	300'	2 hrs

8. WELL CONSTRUCTION
Depth Drilled 554 Feet Depth Cased 554 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
26 Inches		0 Feet	554 Feet
Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
18		.375	+2	256
18		.375	546	554

Perforations:
Type perforation 18" JOHNSON WIRE WRAP SCREENS
Size perforation SLOT SIZE
From 256 feet to 546 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 54'
Placement Method: ☐ Pumped ☒ Poured

Seal Type: ☐ Neat Cement ☒ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 54' feet to 554' feet

9. WATER LEVEL
Static water level 38' feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature 61 °F Quality GOOD

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name RIVERSIDE INC. (Contractor)
Address P.O. BOX 720 (Contractor)
PARMA, ID 83660
Nevada contractor's license number issued by the State Contractor's Board 0044881
Nevada driller's license number ~~issued by~~ the Division of Water Resources, the on-site driller 2109
Signed [signature] By driller performing actual drilling on site or contractor
Date 4-22-03

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627