Plugged under NOI 61568

WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 88985
Permit No. 31140
Basin 069

NOTICE OF INTENT NO. 31534

1. OWNER WINNEMUCCA FARMS INC
MAILING ADDRESS 1 POTATO PLACE
WINNEMUCCA, NV 89445

ADDRESS AT WELL LOCATION GOLCONDA BUTTE
WELL #11 N41.069405 W117.562240 NAD27

2. LOCATION SW ¼ NW ¼ Sec. 23 T. 37 N/S R. 39 E. HUMBOLDT County

PERMIT NO. 31140, 30591, 26645, 65847 Issued by Water Resources | Parcel No. | Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☒ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☒ Other REVERSE

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
TOP SOIL		0	14	14
BURNT CLAY		14	38	24
SAND + PEA GRAVEL		38	88	50
TAN CLAY		88	96	8
COARSE SAND, PEA GRAVEL		96	131	35
BROWN CLAY		131	160	29
FINE-COARSE SAND		160	167	7
BR CLAY		167	320	153
BROKEN BASALT W/GRAVEL		320	345	25
BASALT		345	453	108
RED CLAY STONE, GRAVE, CINDERS		453	463	10
BURNT CLAY		463	469	6
BROKEN ROCK W/CINDERS		469	630	161
BRN CLAY W/ROCK, CINDERS		630	634	4
BROKEN ROCK, CINDERS		634	640	6

NOTE: 2500# BENTONITE FROM 280' to 300'

RECEIVED 03 JAN 21 PM 1:01 STATE ENGINEER'S OFFICE

Date started OCTOBER 30, 2002
Date completed DECEMBER 21, 2002

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
3200	197'	5 hr

8. WELL CONSTRUCTION
Depth Drilled 640 Feet Depth Cased 640 Feet

HOLE DIAMETER (BIT SIZE)

Inches	From Feet	To Feet
24	0	640

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
18	70.59	.375	+2	322
18	70.59	.375	360	400

Perforations:
Type perforation 18" JOHNSON WIRE WRAP SCREENS
Size perforation SLOT SIZE .040
From 320 feet to 360 feet
From 400 feet to 640 feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50'
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☒ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 280' to 640' feet

9. WATER LEVEL
Static water level 40 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature 60 °F Quality GOOD

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name RIVERSIDE, INC. (Contractor)
Address PO BOX 720 (Contractor)
PARMA, ID 83660
Nevada contractor's license number issued by the State Contractor's Board 0044881
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2109
Signed Kevin Chastain (By driller performing actual drilling on site or contractor)
Date 1-6-03

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627