


COPIES TO  
 - DIVISION OF WATER RESOURCES  
 - CLIENT'S COPY  
 - WELL DRILLER'S COPY

STATE OF NEVADA  
 DIVISION OF WATER RESOURCES



OFFICE USE ONLY

Log No. 88991

Permit No. \_\_\_\_\_

Basin 103

NOTICE OF INTENT NO. 49408

PRINT OR TYPE ONLY

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

1. OWNER KEVIN TREMAYNE  
 MAILING ADDRESS 1769 PINION HILLS DR  
CARSON CITY, NV 89703  
 ADDRESS AT WELL LOCATION 1769 PINION HILLS DR  
CARSON CITY, NV 89703

2. LOCATION NE NE 23 E 15 N R 20 E CARSON County  
 PERMIT NO. 10-096-1 PINION HILLS AREA  
Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other MUD

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
BLOW SANDS		0	3	3
HARDPAN CLAY		3	6	3
COURSE DG SANDS		6	55	49
LOST MUD CIRCULATION/ AIR		55	74	19
VOLCANIC SANDS		74	143	69
CLAY STRATA		143	158	15
VERY FRACTURED VOLCANIC SANDS & GRAVELS	XXX	158	180	22

8. WELL CONSTRUCTION

Depth Drilled 180 Feet Depth Cased 180 Feet

HOLE DIAMETER (BIT SIZE)

From	To
<u>10 3/4</u> Inches	<u>0</u> Feet <u>180</u> Feet
_____ Inches	_____ Feet _____ Feet
_____ Inches	_____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>13.03</u>	<u>.188</u>	<u>0</u>	<u>180</u>

Perforations:  
 Type perforation FACTORY MILL SLOT  
 Size perforation 3 X 3/32  
 From 160 feet to 180 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 60  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
 Gravel Packed:  Yes  No  
 From 60 feet to 180 feet

9. WATER LEVEL  
 Static water level 80 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. 25+ P.S.I.  
 Water temperature 110 °F Quality GOOD

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name CAPITAL CITY WELL DRILLING  
(CONTRACTOR)

Date started 10/22, 20 02  
 Date completed 10/24, 20 02

7. WELL TEST DATE

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>25+</u>	<u>45</u>	<u>3 HRS</u>

Address 20 KIT KAT DRIVE  
(CONTRACTOR)  
CARSON CITY, NV 89706  
 Nevada contractor's license number issued by the State Contractor's Board 41775  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2157  
 Signed Rick Crane  
 By driller performing actual drilling on site or contractor  
 Date 11/1/02