

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO 24042

1. OWNER Terry Bird ADDRESS AT WELL LOCATION Two miles south of Orsino on Rose Valley Road
 MAILING ADDRESS PO. Box 158 Pioche NV 89043
 2. LOCATION SW 1/4 NW 1/4 Sec 11 T. 1 R. 69 E. Lincoln County
 PERMIT NO. 006-271-29 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>Top Gravel - Boulders</u>		<u>0</u>	<u>80</u>	<u>80</u>
<u>fine gravel</u>	<u>2</u>	<u>80</u>	<u>84</u>	<u>4</u>
<u>Boulders - sand</u>	<u>2</u>	<u>84</u>	<u>104</u>	<u>20</u>
<u>Hard Rock</u>		<u>104</u>	<u>107</u>	<u>3</u>

DCNR/DWR RECEIVED
 APR 21 2003
 AS VEGAS OFFICE

8. WELL CONSTRUCTION
 Depth Drilled 107 Feet Depth Cased 107 Feet
 HOLE DIAMETER (BIT SIZE)
 From 10 5/8 Inches To 8 Feet 107 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 1/2</u>		<u>3/4</u>	<u>0</u>	<u>107</u>

Perforations:
 Type perforation jaw cut
 Size perforation 1 3/8" x 6"
 From 57' feet to 107 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Neat Cement
 Depth of Seal 50 Cement Grout
 Placement Method: Pumped Poured Concrete Grout
 Gravel Packed: Yes No
 From 50 feet to 107 feet

9. WATER LEVEL
 Static water level 17 feet below land surface
 Artesian flow _____ G.P.M. P.S.I.
 Water temperature cold °F Quality good

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name David Drilling and Pumps Contractor
 Address HC 61 Box 54 Hiko NV 89007 Contractor
 Nevada contractor's license number issued by the State Contractor's Board 0028266
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1191
 Signed Mike Davis
 By driller performing actual drilling on site or contractor
 Date 3-16-03

Date started 3-03-03 19____
 Date completed 3-15-03 19____

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>6</u>	<u>80</u>	<u>1</u>