WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

# WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 88998
Permit No.
Basin 209

NOTICE OF INTENT NO. 24040

1. OWNER Alamo Sewer and water
MAILING ADDRESS PO Box 418
Alamo NV 89001

ADDRESS AT WELL LOCATION 1/2 mile south of alamo west side of valley

2. LOCATION N/E ¼ SW ¼ Sec. 8 T. 7 N/S R. 61 E. Lincoln County
PERMIT NO. (Issued by Water Resources) 008-031-52 (Parcel No.) (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| Sand Boulders | | 0 | 42 | 42 |
| Clay - Boulders | | 42 | 56 | 14 |

Schedule 40 Flush threaded pipe was used in this well

A seven foot piece of 6" steel casing was cemented over 4" pipe and locking cap installed

Date started 4-21-03, 19
Date completed 4-22-03, 19

7. WELL TEST DATA
TEST METHOD: ☒ Bailer ☐ Pump ☐ Air Lift

| G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|---|---|---|
| 3 | 4 | 4 |

8. WELL CONSTRUCTION
Depth Drilled 56 Feet Depth Cased 55 Feet

HOLE DIAMETER (BIT SIZE)

| | | From | To |
|---|---|---|---|
| 8 Inches | | 0 Feet | 56 Feet |
| Inches | | Feet | Feet |
| Inches | | Feet | Feet |

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|---|---|---|---|---|
| 4 | | Sch 40 | 0 | 55 |
| | | | | |
| | | | | |

Perforations:
Type perforation Screen
Size perforation 30 thousandth slot
From 15 feet to 45 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 13
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 15 feet to 55 feet

9. WATER LEVEL
Static water level 19 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature cold °F Quality good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Dennis Drilling and Pumps (Contractor)
Address HC 61 Box 54 Alto NV 89017 (Contractor)

Nevada contractor's license number issued by the State Contractor's Board 0028266
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1191
Signed Mike Dennis (By driller performing actual drilling on site or contractor)
Date 4-24-03

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627