WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 39042
Permit No.
Basin 088

NOTICE OF INTENT NO. 50351

1. OWNER Daniel Schochet
MAILING ADDRESS 5485 Wild Wood Dr Reno, NV 89511
ADDRESS AT WELL LOCATION 5485 Wildwood Dr. Reno, Nev 89511

2. LOCATION NW ¼ NW ¼ Sec. 2 T. 17 N S R 19 E County
PERMIT NO. WL 020089 (Issued by Water Resources) 0455 4219 (Parcel No.) Subdivision Name

3. WORK PERFORMED
☐ New Well ☒ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Brown Sand + Boulders		0	3	3
Brown Clay		3	5	2
Brown Clay + Boulders		5	17	12
Black + White Boulders		17	30	13
Brown Clay		30	32	2
Black, White, Grey Rock		32	60	28
Black, Grey, Green White Rock		60	160	100
Brown Clay		160	175	15
White, Brown, Green, Black Rock		175	230	55
Sand + Broken Rock		230	240	10
Black, Grey, White, Green Dg		240	400	160
Light Brown Clay + D. Gr.		400	410	10
White, Brown, Green, Black + Red Rock		410	560	150
Dark Brown Clay		560	618	58

RECEIVED 02 DEC 17 AM 11:20 STATE ENGINEERS OFFICE

Date started 8-5-02, 20
Date completed 8-14-02, 20

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
50-100		4

8. WELL CONSTRUCTION
Depth Drilled 618 Feet Depth Cased 618 Feet

HOLE DIAMETER (BIT SIZE)
10⅝ Inches From 0 Feet To 618 Feet
Inches Feet Feet
Inches Feet Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6⅝		.188	0	618

Perforations:
Type perforation FACTORY
Size perforation
From 498 feet to 558 feet
From 318 feet to 358 feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout
Gravel Packed: ☒ Yes ☐ No
From 618 feet to 50 feet

9. WATER LEVEL
Static water level 162 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature Cold °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Nevada Pump + Drilling (Contractor)
Address PO Box 3227 (Contractor)
Dayton NV 89403
Nevada contractor's license number issued by the State Contractor's Board 0046357
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2187
Signed Thomas Evans (By driller performing actual drilling on site or contractor)
Date 8-19-02

(Rev. 12-01)

USE ADDITIONAL SHEETS IF NECESSARY

(O)-627