Summer Camp pit well

WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 89052
Permit No.
Basin 0660

NOTICE OF INTENT NO. 44401

1. OWNER Getchell/Placer Dome
MAILING ADDRESS P.O Box 220
Golconda, NV 89414

ADDRESS AT WELL LOCATION AT Mine Site North of Golconda

2. LOCATION SW ¼ SE ¼ Sec. 9 T 38 N/S R 42 E Humboldt County
PERMIT NO. N/A Issued by Water Resources
UNSURVEYED Parcel No.
N/A Subdivision Name

3. WORK PERFORMED
☐ New Well ☒ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Topsoil		1	5	5
Shale Black		5	30	25
Intrusive		30	40	10
Black shale		40	120	80
limestone		120	140	20
Shale Black		140	200	60
limeston	XX	200	220	20
hole Caved in From 225 to 220 Before we could get Casing on Bottom				
Cement		40	0	
hole Plug		89	40	
Abantonite		133	89	
Hole Plug		143	133	
Sand		143	220	

RECEIVED JAN 21 PM 1:07 ENGINEERS OFFICE

Date started Dec 9, 2002
Date completed Dec 12, 2002

7. WELL TEST DATA

TEST METHOD: ☐ Bailer ☒ Pump ☐ Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
SQIOF	10	None	22 hrs

8. WELL CONSTRUCTION
Depth Drilled 225 Feet Depth Cased 220 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
8" Inches		20 Feet	225 Feet
12 3/4 Inches		0 Feet	20 Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8 5/8	16	.188	+1	20
4"		Sch 80 1/4+	+1	220

Perforations:
Type perforation Plastic Screen
Size perforation 0.20
From 160 feet to 220 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 143'
Placement Method: ☒ Pumped ☐ Poured
Seal Type: 40' of ← ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 143 feet to 220 feet

9. WATER LEVEL
Static water level 151.6 feet below land surface
Artesian flow N/A G.P.M. N/A P.S.I.
Water temperature Cool °F Quality Fair

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Fred Anderson Drilling Inc (Contractor)
Address 10760 Grass Valley Road (Contractor)
Winnemucca, NV 89445
Nevada contractor's license number issued by the State Contractor's Board 021467
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 01375
Signed (By driller performing actual drilling on site or contractor)
Date 12-30-02

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627