

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 21661

1. OWNER Fred White
 MAILING ADDRESS H.C. 69, Box 416
Amargosa Valley, Nv. 89020
 ADDRESS AT WELL LOCATION Atomic Street
Amargosa Valley, Nv. 89020
 2. LOCATION NE 1/4 NW 1/4 Sec. 8 T 16 N 49 E County NYE
 PERMIT NO. 19-222-18 Parcel No. _____
 Issued by Water Resources _____ Subdivision Name J+S Subdivision

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
top soil		0	9	9
caliche		9	13	5
gravel w/ sand		13	155	142
limestone		155	160	5
sand		160	170	10
limestone		170	175	5
gravel	1st	175	195	20
limestone		195	202	7
gravel w/ sand		202	240	38
sand		240	250	10
Bottom of Hole 250				

DCNR/DWR
RECEIVED
MAY 12 2003
LAS VEGAS OFFICE

8. WELL CONSTRUCTION
 Depth Drilled 250 Feet Depth Cased 250 Feet
 HOLE DIAMETER (BIT SIZE)
 From 12 1/4 Inches To 0 Feet 250 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet
 CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6	PVC		0	250
Surface Protective Casing:				
8	steel	.188	0	7

 Perforations: Machined
 Type perforation _____
 Size perforation 3" x 1/8" every 12"
 From 170 feet to 210 feet
 From 230 feet to 240 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 Surface Seal: Yes No Seal Type:
 Depth of Seal 50 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 50 feet to 250 feet

Date started 3-31-03 19_____
 Date completed 4-3-03 19_____
 7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

9. WATER LEVEL
 Static water level 161 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Cook Drilling Co.
 Address H.C.R. 70, Box 543
Amargosa Valley, Nv. 89020
 Nevada contractor's license number 5376-A
 issued by the State Contractor's Board.
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2160
 Signed Roy Johns
 By driller performing actual drilling on site or contractor
 Date _____