

STATE OF NEVADA
 DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
 Log No. 89103
 Permit No. _____
 Basin 061

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 48587

1. OWNER Barrick Goldstrike Mines PZ-96-7
 MAILING ADDRESS P.O. Box 29
Elko, NV 89803

ADDRESS AT WELL LOCATION Barrick Goldstrike minesite, north of Carlin, NV

2. LOCATION SW 1/4 NW 1/4 Sec. 29 T 36N N/S R 50E E Eureka County
 PERMIT NO. M/O-441A Issued by Water Resources Parcel No. N/A Subdivision Name N/A

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Abandoned by pumping neat cement down both tubes from T.D. to surface.				
<i>Dual Completion</i>				
Quantities Used:				
1: 13.9 cu.ft				
2: 4.8 cu.ft.				

Original Construction Detail:

	From	To	Thickness
Cement	0	51	51
Hole plug	51	268	217
Gravel pack	268	298	30
Hole plug	298	424	126
Gravel pack	424	452	28
Cement	452	800	348

Date started 4/11/2003, 19
 Date completed 4/11/2003, 19

7. WELL TEST DATA

TEST METHOD:	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift	G.P.M.	

8. WELL CONSTRUCTION

Depth Drilled 800 Feet Depth Cased 450 Feet
 HOLE DIAMETER (BIT SIZE)
 From To
12.25 Inches 0 Feet 40 Feet
6.25 Inches 40 Feet 800 Feet
 Inches Feet Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>7.625</u>	<u>23.57</u>	<u>0.301</u>	<u>0</u>	<u>40</u>
<u>1: 1.25</u>	<u>2.273</u>	<u>0.140</u>	<u>+2</u>	<u>450</u>
<u>2: 1.25</u>	<u>2.273</u>	<u>0.140</u>	<u>+2</u>	<u>297</u>

Perforations:
 Type perforation Mill Slot
 Size perforation 0.125"
 From 1: 430 feet to 450 feet
 From 2: 277 feet to 297 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type: Neat Cement
 Depth of Seal 51' Cement Grout
 Placement Method: Pumped Poured Concrete Grout
 Gravel Packed: Yes No
 From See Detail feet to _____ feet

9. WATER LEVEL

Static water level 1: 426 2: 204 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Lang Exploratory Drilling Contractor
 Address P.O. Box 5279 Contractor
Elko, NV 89802-5279
 Nevada contractor's license number issued by the State Contractor's Board 0021976
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1716
 Signed Dave H. [Signature]
 By driller performing actual drilling on-site or contractor
 Date 4/18/03

B.S.T.C