COPIES TO
- DIVISION OF WATER RESOURCES
- CLIENT'S COPY
- WELL DRILLER'S COPY

PRINT OR TYPE ONLY

STATE OF NEVADA

DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 89134
Permit No.
Basin 105

NOTICE OF INTENT NO. 49446

1. OWNER NICK KATSARIS CONSTRUCTION
MAILING ADDRESS 2991 HOT SPRINGS RD
MINDEN, NV 89423

ADDRESS AT WELL LOCATION 2029 ROCKING HORSE
GARDNERVILLE, NV 89410

2. LOCATION NW ¼ NW ¼ Sec 19 T 12 N R 21 E Douglas County
PERMIT NO. (Issued by Water Resources) 1221-19-001-014 (Parcel No.) (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other MUD

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
HARDPAN CLAY		0	6	6
BROWN CLAY		6	34	28
COURSE GRAVELS		34	89	55
SMALL OBSIDIAN GRAVELS		89	152	63
BROWN CLAY STRATA		152	210	58
SMALL SANDS AND CLAY STRATAS		210	238	28
FRACTURED GRAVELS	XXX	238	280	42

Date started 2/1, 20 03
Date completed 2/3, 20 03

RECEIVED 03 FEB 14 AM 11:17 STATE ENGINEERS OFFICE

7. WELL TEST DATE
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
25	65	3 HRS

8. WELL CONSTRUCTION
Depth Drilled 280 Feet Depth Cased 280 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
10 3/4 Inches	0 Feet	280 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	13.03	.188	0	280

Perforations:
Type perforation FACTORY MILL SLOT
Size perforation 3X 3/32
From 260 feet to 280 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No Seal Type:
Depth of Seal 55 ☐ Neat Cement
Placement Method: ☐ Pumped ☐ Cement Grout
☒ Poured ☐ Concrete Grout
Gravel Packed: ☒ Yes ☐ No
From 55 feet to 280 feet

9. WATER LEVEL
Static water level 120 feet below land surface
Artesian flow G.P.M 25 P.S.I
Water temperature COLD °F Quality GOOD

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name CAPITAL CITY WELL DRILLIG (CONTRACTOR)
Address 20 KIT KAT DRIVE (CONTRACTOR)
CARSON CITY, NV 89706
Nevada contractor's license number issued by the State Contractor's Board 41775
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2157
Signed Rick Crane
By driller performing actual drilling on site or contractor
Date 2/4/03