COPIES TO
- DIVISION OF WATER RESOURCES
- CLIENT'S COPY
- WELL DRILLER'S COPY

PRINT OR TYPE ONLY

STATE OF NEVADA

DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 89137
Permit No.
Basin 104

NOTICE OF INTENT NO. 49449

1. OWNER BOB FREDLUND CONSTRUCTION
MAILING ADDRESS 4310 OLD CLEAR CREEK RD
CARSON CITY , NV 89703

ADDRESS AT WELL LOCATION 4340 OLD CLEAR CREEK
CARSON CITY , NV 89703

2. LOCATION SE ¼ SE ¼ Sec 32 T 15 N R 19 E CARSON County

PERMIT NO. (Issued by Water Resources) | 7-042-23 (Parcel No.) | (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☒ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
COURSE DG SANDS		0	3	3
DG SANDS RUSTY		3	36	33
SOFT DG SANDS		36	110	74
RUSTY GRANITE		110	178	68
HARD DG GRANITE LIGHT GRAY		178	195	17
FRACTURED GRANITE RUSTY AND COLORED	XXX	195	220	25

RECEIVED 03 FEB 27 AM 11:19 STATE ENGINEERS OFFICE

Date started 2/5 , 20 03
Date completed 2/9 , 20 03

7. WELL TEST DATE

TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
30+	40	3 HRS

8. WELL CONSTRUCTION

Depth Drilled 220' Feet Depth Cased 220' Feet

HOLE DIAMETER (BIT SIZE)

	From	To
10 3/4 Inches	0 Feet	220 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	13.03	.188	0	220

Perforations:
Type perforation FACTORY MILL SLOT
Size perforation 3 X 3/32
From 200 feet to 220 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No Seal Type:
Depth of Seal 100 ☒ Neat Cement
Placement Method: ☒ Pumped ☐ Cement Grout
☐ Poured ☐ Concrete Grout
Gravel Packed: ☒ Yes ☐ No
From 100 feet to 220 feet

9. WATER LEVEL
Static water level 35 feet below land surface
Artesian flow G.P.M ~~30+~~ P.S.I
Water temperature COLD °F Quality GOOD

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name CAPITAL CITY WELL DRILLING (CONTRACTOR)
Address 20 KIT KAT DRIVE (CONTRACTOR)
CARSON CITY , NV 897076
Nevada contractor's license number issued by the State Contractor's Board 41775
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2157
Signed Rick Crane
By driller performing actual drilling on site or contractor
Date 2/10/03

(Rev 3-91) USE ADDITIONAL SHEETS IF NECESSARY

Forms Provided by Forms-On-A-Disk, Inc. · Dallas, Texas · (214) 340-9429