WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 89139
Permit No.
Basin 105

NOTICE OF INTENT NO. 47948

1. OWNER Ray Bacon
MAILING ADDRESS 780 Pawnee St Carson City NV 89705
ADDRESS AT WELL LOCATION 780 Pawnee St Carson City NV 89705

2. LOCATION SW ¼ NE ¼ Sec. 12 T. 14 N/S R. 19 E. Douglas County
PERMIT NO. — Issued by Water Resources | 141942-610-022 Parcel No. | — Subdivision Name

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☒ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Silty Clay		108	124	
Clay + DG		124	144	
DG w/ Black Rocks		144	304	
Med Quartz Sand				
Some clay layers				
Clayey Sand		304	344	
Layers - Coarse				
Quartz Sand				
Layers with				
Black Rock +				
Black Fine Sand				

RECEIVED
03 APR -9 AM 10:31
STATE ENGINEERS OFFICE

Date started 2-25-03, 19
Date completed 2-28-03, 19

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
40-50		25+

8. WELL CONSTRUCTION
Depth Drilled 344 Feet Depth Cased 344 Feet

HOLE DIAMETER (BIT SIZE)
7 7/8 Inches From 108 Feet To 344 Feet
Inches Feet Feet
Inches Feet Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
5 9/16		.188	100	139
			159	201
			241	283
			303	324

Perforations:
Type perforation Factory slot
Size perforation 1/16" x 3"
From 139 feet to 159 feet
From 201 feet to 241 feet
From 283 feet to 303 feet
From 324 feet to 344 feet
From feet to feet

Surface Seal: ☐ Yes ☒ No
Depth of Seal
Placement Method: ☐ Pumped ☐ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☐ Yes ☐ No ☒ Natural
From feet to feet

9. WATER LEVEL
Static water level 61 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature 60 °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Sierra Nevada Drilling + Pump Contractor
Address 3540 Green Acres Dr Contractor
Carson City NV 89705
Nevada contractor's license number issued by the State Contractor's Board 52078
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1902
Signed [signature] By driller performing actual drilling on site or contractor
Date 3-25-03

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627