

OFFICE USE ONLY
 Log No. 89164
 Permit No. _____
 Basin 105

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 47038

1. OWNER Bob Ballou ADDRESS AT WELL LOCATION 2622 ERINET MINDEN NV 89423
 MAILING ADDRESS 2980 SAN MATEO PR MINDEN NV 89423
 2. LOCATION NW 1/4 SE 02 T 13 N 20 E Douglas County
 PERMIT NO. 132002002069 Issued by Water Resources Parcel No. _____ Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
SAND - COBBLES		0	3	3
Chaleiche		3	5	2
FINE SAND - silt w/ intermittent clay layers		5	200	195
MEDIUM SAND	X	200	220	20
COARSE SAND	X	220	240	20
Silty clay		240	265	25
MEDIUM SAND	X	265	302	37
COARSE SAND				

8. WELL CONSTRUCTION
 Depth Drilled 302 Feet Depth Cased 302 Feet
 HOLE DIAMETER (BIT SIZE)
 From 10 5/8 Inches To 0 Feet 302 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>		<u>.188</u>	<u>+1</u>	<u>220</u>
<u>6 5/8</u>		<u>.188</u>	<u>240</u>	<u>282</u>

Perforations:
 Type perforation factory slot
 Size perforation 3/32" x 3"
 From _____ feet to _____ feet
 From 220 feet to 240 feet
 From _____ feet to _____ feet
 From 282 feet to 302 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 50' Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 50 feet to 302 feet

9. WATER LEVEL
 Static water level 160 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature cool °F Quality _____

Date started 1-21-03, 19____
 Date completed 1-24-03, 19____

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>50+-</u>		<u>2 hrs</u>

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Sierra Nv Drilling + Pump LLC Contractor
 Address 3540 Green Acres Dr Carson City NV 89705 Contractor
 Nevada contractor's license number 52078 issued by the State Contractor's Board
 Nevada driller's license number issued by the 1902 Division of Water Resources, the on-site driller
 Signed John S. Lewis
 By driller performing actual drilling on site or contractor
 Date 2-17-03