mw-97

WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 89172
Permit No.
Basin 104

NOTICE OF INTENT NO. 49509

1. OWNER Silver Oak Dev.
MAILING ADDRESS 3075 College Dr Carson City NV
ADDRESS AT WELL LOCATION Silver Oak Golf Course Fairway 1 Carson City NV

2. LOCATION NW ¼ SW ¼ Sec. 6 T. 15 (N)S R. 20 E. County
PERMIT NO. (Issued by Water Resources) 806209 (Parcel No.) Lot 2 (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☒ Other Sonic

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Soils clayey sand		0	9	9
Sand Tan		9	17	8
Saturated sand		17	28	11
Sandy clay		28	32	4
Sandy gray		32	37	5
Sand clay brn		37	49	12
Sandy clay reddish brn		49	52	3
Sand (loose, gray)		52	57	5
Clayey sand red gray		57	62	5
Sand course gray		62	64	2
gray silty clay		64	67	3
Sand gray		67	70	3
Clay gray		70	72	2
Sand gray course		72	80	8
Silty Sand		80	100	20
Sand		100	120	20
Silty Sand		120	130	10
Silty sand with some clays		130	147	17
Silty Sand gravels		147	157	10
Sand/gravels reddish gray		157	165	8

Date started 2-3, 2003
Date completed 2-5, 2003

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 165 Feet Depth Cased 165 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
8 Inches	0 Feet	165 Feet	
Inches	Feet	Feet	
Inches	Feet	Feet	

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
4"		Sch 80	0	65
4"		Sch 80	95	135

Perforations:
Type perforation Factory
Size perforation .020
From 65 feet to 95 feet
From 135 feet to 165 feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 63
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 62'-98' feet to 132'-165' feet

9. WATER LEVEL
Static water level 40' feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Boart Longyear (Contractor)
Address PO Box 1000 (Contractor)
Dayton NV 89403
Nevada contractor's license number issued by the State Contractor's Board 0010157
Nevada driller's license number issued by the Division of Water Resources, the on-site driller M 2222
Signed Bruce Anderson (By driller performing actual drilling on site or contractor)
Date 2-15-03

(Rev. 12-01) USE ADDITIONAL SHEETS IF NECESSARY (O)-627