15

WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 89173
Permit No.
Basin 104

NOTICE OF INTENT NO. 49510

1. OWNER Silver Oaks Dev
MAILING ADDRESS 3075 College Dr
Carson City NV

ADDRESS AT WELL LOCATION Silver Oaks Golf Course
Carson City NV

2. LOCATION NW ¼ SW ¼ Sec. 6 T. 15 N/S R. 20 E. County
PERMIT NO. Issued by Water Resources | 8-062-09 Parcel No. | Silver Oaks PH 4 Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☒ Other Sonic

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Soils		0	4	4
Silty clay		4	7	3
Sand		7	15	8
Reddish brn sand		15	22	7
Sand - gravels		22	26	4
Sand - (grey)		26	36	10
Clays		36	37	1
Reddish brn sand		37	39	2
Clays + sand		39	41	2
Sand		41	43	2
Silty sand gray with clay seams		43	63	20
Reddish brn silty sand		63	68	5
Reddish clay		68	76	8
gray clay + sand		76	81	5
Clayey sands		81	86	5
Silty sands		86	91	5
Sand with silt seams		91	111	20
Clay		111	116	5
Sand (gray)		116	126	10
Clayey sands		126	134	8
Sand		134	143	9
Silty sand		143	149	6
Sand		149	156	7
Clayey sand		156	158	2
Clay		158	165	7

Date started Feb 26, 2003
Date completed Feb 28, 2003

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled ____ Feet Depth Cased ____ Feet

HOLE DIAMETER (BIT SIZE)

		From	To
8 Inches	0 Feet	165 Feet	
Inches	Feet	Feet	
Inches	Feet	Feet	

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
4		Sch 80	0	45
4		Sch 80	85	125

Perforations:
Type perforation Factory
Size perforation .020
From 45 feet to 85 feet
From 125 feet to 165 feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 42
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 42 - 88 feet to 122 165 feet

9. WATER LEVEL
Static water level 48' feet below land surface
Artesian flow ____ G.P.M. ____ P.S.I.
Water temperature ____ °F Quality ____

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Boart Longyear Co (Contractor)
Address PO Box 1000 (Contractor)
Dayton NV 89403
Nevada contractor's license number issued by the State Contractor's Board 0010157
Nevada driller's license number issued by the Division of Water Resources, the on-site driller M 2222
Signed Bruce Anderson (By driller performing actual drilling on site or contractor)
Date 2-28-03

(Rev. 12-01) USE ADDITIONAL SHEETS IF NECESSARY (O)-627