

WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

OFFICE USE ONLY
Log No. 89115
Permit No. _____
Basin 104

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 49510

1. OWNER Silver Oak Dev ADDRESS AT WELL LOCATION _____
MAILING ADDRESS 3075 College Dr Silver Oaks Golf Course Fairway 18
Carson City NV Carson City NV
2. LOCATION NW 1/4 SW 1/4 Sec. 6 T. 15 S. R. 20 E. County _____
PERMIT NO. 8-062-09 Lot 2 Silver Oaks phase 4 Parcel No. _____ Subdivision Name _____
Issued by Water Resources _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
5. WELL TYPE
 Cable Rotary RVC
 Air Other Senis

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Soils		0	4	4
Silty sand brn		4	10	6
Sand reddish brn seams	17'	10	20	10
Silty sand light gray		20	30	10
Sand		30	40	10
Silty sand gray		40	50	10
Sand reddish brn		50	53	3
Sand gray		53	72	19
Clay reddish		72	73	1
Dark gray silty sand		73	82	9
Silty sand reddish		82	95	13
Silty sand gray		95	100	5
Sand gray		100	113	13
Clayey sand		113	120	7
Clay gray		120	125	5
Silty sand gray/brn		125	140	15
Sand		140	150	10
Clayey sand gray		150	155	5
Sand gray		155	165	10

8. WELL CONSTRUCTION
Depth Drilled 165 Feet Depth Cased 165 Feet
HOLE DIAMETER (BIT SIZE)
From To
8 Inches 0 Feet 165 Feet
Inches Feet Feet
Inches Feet Feet
CASING SCHEDULE
Size O.D. (Inches) Weight/Ft. (Pounds) Wall Thickness (Inches) From (Feet) To (Feet)
4 Sch 80 0 25
4 Sch 80 65 95
4 Sch 80 145 165
Perforations:
Type perforation Factory
Size perforation 0.70
From 25 feet to 65 feet
From 95 feet to 125 feet
From 145 feet to 165 feet
From feet to feet
From feet to feet
Surface Seal: Yes No Seal Type:
Depth of Seal 23' Neat Cement
Placement Method: Pumped Cement Grout
 Poured Concrete Grout
Gravel Packed: Yes No
From 23 - 68' / 92' - 129' feet to 142 - 165' feet

Date started 2-13, 2003
Date completed 2-19, 2003

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			

9. WATER LEVEL
Static water level 20' feet below land surface
Artesian flow _____ G.P.M. _____ P.S.I.
Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Boart Longyear Contractor
Address P.O. Box 1000 Contractor
Dayton NV 89403
Nevada contractor's license number issued by the State Contractor's Board 0010157
Nevada driller's license number issued by the Division of Water Resources, the on-site driller M-2222
Signed Bruce Anderson
By driller performing actual drilling on site or contractor
Date 2-20-03