

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO 49510

1. OWNER Silver Oaks Dev ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS 3075 College Dr Silver Oaks Golf Course Phase 9
Carson City NV Carson City NV
 2. LOCATION NW 1/4 SW 1/4 Sec 6 T 15 N R 20 E County _____
 PERMIT NO. 8-062-09 Lot 2 Silver Oaks phase 4
 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other Senic

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Soils		0	4	4
Sand		4	20	16
Silty sand		20	27	7
Sand light gray		27	40	13
Sand dark gray		40	45	
small gravels	40/45	L		
Silty sand		45	60	15
course sand seams				
silty sand reddish brown		60	65	5
light gray silty sand		65	85	20
gray sand reddish brown seams		85	95	10
Dark gray clayey sand		95	102	7
Reddish brown clayey sand		102	107	5
Reddish gray sand		107	114	7
Light gray sand		114	140	26
Dark gray clayey sand		140	165	15

8. WELL CONSTRUCTION
 Depth Drilled 165 Feet Depth Cased 165 Feet
 HOLE DIAMETER (BIT SIZE)
 From To
8 Inches 0 Feet 165 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
4		Sch 80	0	45
4		Sch 80	85	125

Perforations:
 Type perforation Factory
 Size perforation .020
 From 45 feet to 85 feet
 From 125 feet to 165 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout
 Depth of Seal 43
 Placement Method: Pumped Poured
 Gravel Packed: Yes No
 From 43' - 88' feet to 122' - 165' feet

9. WATER LEVEL
 Static water level 70' feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Boart Longyear Co Contractor
 Address PO Box 1000 Contractor
Dayton NV 89403
 Nevada contractor's license number issued by the State Contractor's Board 0010157
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller M.2222
 Signed Bruce Anderson
 By driller performing actual drilling on site or contractor
 Date 2-20-03

Date started 2-10, 2003
 Date completed 2-12, 2003

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			