

STATE OF NEVADA
 DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
 Log No. 89201
 Permit No. 28629
 Basin 105

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

Please complete this form in its entirety in
 accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 50265

1. OWNER **Syncom Homes** ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS **2221 Meridian Blvd**
Minden, NV 89423

2. LOCATION NW 1/4 SW 1/4 Sec. 35 T 14N N/S R 20E E Douglas County
 PERMIT NO. 28629 Issued by Water Resources Parcel No. 1420-35-401-003 Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition Domestic
 Deepen Abandon Other _____
 Municipal/Industrial Irrigation Monitor Test Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Drill fill material out well from 60 ft. to 135 ft. Drill would not advance any further				
Perforated well - 5 rows with holt perforator down to 120 ft.				
Set trimmie pipe and pumped 10,810 lbs of neat cement from 135 ft. to surface				
ABANDONMENT				

8. WELL CONSTRUCTION
 Depth Drilled 135 Feet Depth Cased N/A Feet

HOLE DIAMETER (BIT SIZE)
 From To
10-3/4 Inches 0 Feet 135 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)

Perforations:
 Type perforation Holt perforator
 Size perforation 1/8 x 1

From <u>0</u> feet to <u>120</u> feet
From _____ feet to _____ feet
From _____ feet to _____ feet
From _____ feet to _____ feet
From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 135 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout

Gravel Packed: Yes No
 From _____ feet to _____ feet

9. WATER LEVEL
 Static water level none feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name **Humboldt Drilling & Pump Co., Inc.** Contractor
 Address **4675 W. Winnemucca Blvd** Contractor
Winnemucca, Nevada 89445
 Nevada contractor's license number issued by the State Contractor's Board 015234
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1713

Signed Jerry A. Long
 By driller performing actual drilling on-site or contractor
 Date 3/15/03

Date started 3/10/03, 19____
 Date completed 3/13/03, 19____

7. WELL TEST DATA

TEST METHOD:	Bailer		Pump	Air Lift
	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)	

RECEIVED
 20 MAR 18 AM 10:47
 STATE ENGINEERING OFFICE