WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 89235
Permit No.
Basin 104

NOTICE OF INTENT NO. 49510

1. OWNER Silver Oak Dev.
MAILING ADDRESS 3075 College Dr
ADDRESS AT WELL LOCATION Silver Oak Golf Course - Fairway 9

2. LOCATION NW ¼ SW ¼ Sec. 6 T. 15 N/S R. 20 E. Doug/NS County
PERMIT NO. (Issued by Water Resources) LOT 2 (Parcel No.) Silver Oak pk 4 (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☒ Other Sonic

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Soils Clayey Sand		0'	13'	13'
Sandy Silt Tan		13'	23'	10'
Saturated Sand - Coarse		23'	30'	7'
Gravely Sand		30'	42'	12'
Clayey Sand - Red, Grey		42'	62'	20'
Sand - Grey - Coarse		62'	83'	21'
Silty Sand some clay		83'	97'	14'

Date started 3-12-03
Date completed 3-14-03

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 97 Feet Depth Cased 80' Feet

HOLE DIAMETER (BIT SIZE)

		From	To
8" Inches		0 Feet	80' Feet
6" Inches		80 Feet	97' Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
4"	sch 80		60	40
4"	sch 80"		10'	0

Perforations:
Type perforation factory
Size perforation .020
From 80 feet to 60 feet
From 40 feet to 10 feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 90-8' Bentonite chips
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout 40'-80'
Gravel Packed: ☒ Yes ☐ No
From 80 feet to 68 feet

9. WATER LEVEL
Static water level 19' feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Robert Conyers (Contractor)
Address Box 1000 (Contractor)
Dayton, NV 89403
Nevada contractor's license number issued by the State Contractor's Board 0001157
Nevada driller's license number issued by the Division of Water Resources, the on-site driller M-2198
Signed (By driller performing actual drilling on site or contractor)
Date 3/15/03

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627