

COPIES TO
 - DIVISION OF WATER RESOURCES
 - CLIENT'S COPY
 - WELL DRILLER'S COPY

STATE OF NEVADA
 DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
 Log No. 89238
 Permit No. _____
 Basin 105

PRINT OR TYPE ONLY

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 49462

OWNER **LARRY ROBERTS**
 MAILING ADDRESS **1812 STERLING RANCH DRIVE**
GARDNERVILLE, NV 89410

ADDRESS AT WELL LOCATION **1812 STERLING RANCH DR**
GARDNERVILLE, NV 89410

2. LOCATION NW $\frac{1}{4}$ NW $\frac{1}{4}$ Sec 1 T 12 N R 20 E DOUGLAS County

PERMIT NO. 1220-01-002-048

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other MUD

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
OVERBURDEN CLAY		0	3	3
LARGE GRAVELS		3	68	65
BROWN CLAY		68	87	19
COURSE GRAVELS		87	156	69
CLAY SEAMS				
BROWN CLAY SEAM		156	194	38
FRACTURED GRAVELS	XXX	194	240	46

8. WELL CONSTRUCTION
 Depth Drilled 240' Feet Depth Cased 240' Feet

HOLE DIAMETER (BIT SIZE)
 From _____ To _____
10 3/4 Inches 0 Feet 240 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>13.03</u>	<u>.188</u>	<u>0</u>	<u>240</u>

Perforations:
 Type perforation FACTORY MILL SLOT
 Size perforation 3 X 3/32
 From 220 feet to 240 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 100 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 100 feet to 240 feet

9. WATER LEVEL
 Static water level 100' feet below land surface
 Artesian flow _____ G.P.M. 25+ P.S.I.
 Water temperature COLD °F Quality GOOD

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name CAPITAL CITY WELL DRILLING INC.
 (CONTRACTOR)

Address 20 KIT KAT DRIVE
 (CONTRACTOR)
CARSON CITY, NV 89706
 Nevada contractor's license number issued by the State Contractor's Board 41775
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2157

Signed Rick Crane
 By driller performing actual drilling on site or contractor
 Date 4/07/03

Date started 03 APR 14 PM 1:18
 Date completed 4/6, 20 03

7. WELL TEST DATE

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>25+</u>	<u>65</u>	<u>3 HRS</u>

RECEIVED
 03 APR 14 PM 1:18
 STATE ENGINEERS OFFICE