

COPIES TO
 - DIVISION OF WATER RESOURCES
 - CLIENT'S COPY
 - WELL DRILLER'S COPY

STATE OF NEVADA
 DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
 Log No. 8923/9
 Permit No. _____
 Basin 105

PRINT OR TYPE ONLY

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 49454

OWNER **CHERYL WELCH**
 MAILING ADDRESS 2617 Fawn Feague Ct. Minden NV 89423

ADDRESS AT WELL LOCATION **620 WEST FORK VISTA LN. GARDNERVILLE, NV 89410**

2. LOCATION SW 1/4 SW 1/4 Sec 11 T 12 N R 19 E County _____

PERMIT NO. 1219-11-002-020

Issued by Water Resources	Parcel No.	Subdivision Name
3. WORK PERFORMED <input checked="" type="checkbox"/> New Well <input type="checkbox"/> Replace <input type="checkbox"/> Recondition <input type="checkbox"/> Deepen <input type="checkbox"/> Abandon <input type="checkbox"/> Other	4. PROPOSED USE <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Irrigation <input type="checkbox"/> Test <input type="checkbox"/> Municipal/Industrial <input type="checkbox"/> Monitor <input type="checkbox"/> Stock	5. WELL TYPE <input type="checkbox"/> Cable <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> RVC <input type="checkbox"/> Air <input type="checkbox"/> Other MUD

6. LITHOLOGIC LOG				
Material	Water Strata	From	To	Thick-ness
OVERBURDEN		0	3	3
COURSE BLACK SANDS SURFACE WATER	X	3	15	12
COURSE DG SANDS		15	78	63
BROWN SILTY CLAY		78	112	34
COURSE DG SANDS SMALL DG GRAVELS	XXX	112	160	48

8. WELL CONSTRUCTION				
Depth Drilled	<u>160'</u> Feet	Depth Cased	<u>160'</u> Feet	
HOLE DIAMETER (BIT SIZE)				
From		To		
<u>10 3/4</u> Inches	<u>0</u> Feet	<u>160</u> Feet		
Inches	Feet	Feet		
Inches	Feet	Feet		
CASING SCHEDULE				
Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>13.03</u>	<u>.188</u>	<u>0</u>	<u>160</u>
Perforations:				
Type perforation	<u>FACTORY MILL SLOT</u>			
Size perforation	<u>3X 3/32</u>			
From	<u>120</u> feet to	<u>160</u> feet		
From	feet to	feet		
From	feet to	feet		
From	feet to	feet		
From	feet to	feet		
Surface Seal: <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No Seal Type:				
Depth of Seal	<u>100</u>	<input checked="" type="checkbox"/> Neat Cement		
Placement Method:	<input checked="" type="checkbox"/> Pumped	<input type="checkbox"/> Cement Grout		
	<input type="checkbox"/> Poured	<input type="checkbox"/> Concrete Grout		
Gravel Packed:	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No			
From	<u>100</u> feet to	<u>160</u> feet		

Date started 3/10, 20 03
 Date completed 3/11, 20 03

7. WELL TEST DATE			
TEST METHOD:	Bailer	Pump	Air Lift
G.P.M.	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
<u>40+</u>		<u>65</u>	<u>3 HRS</u>

9. WATER LEVEL	
Static water level	_____ feet below land surface
Artesian flow	<u>5 G.P.M</u> 100 P.S.I
Water temperature	<u>COLD</u> °F Quality <u>GOOD</u>
10. DRILLER'S CERTIFICATION	
This well was drilled under my supervision and the report is true to the best of my knowledge.	
Name	<u>CAPITAL CITY WELL DRILLING</u> (CONTRACTOR)
Address	<u>20 KIT KAT DRIVE</u> (CONTRACTOR)
	<u>CARSON CITY, NV 89706</u>
Nevada contractor's license number issued by the State Contractor's Board	<u>41775</u>
Nevada driller's license number issued by the Division of Water Resources, the on-site driller	<u>2157</u>
Signed	<u>Rick Crane</u> By driller performing actual drilling on site or contractor
Date	<u>3/21/03</u>

RECEIVED
 03 APR 14 PM 1:18
 STATE ENGINEERS OFFICE