

12-2

WHITE-DIVISION OF WATER RESOURCES  
CANARY-CLIENT'S COPY  
PINK-WELL DRILLER'S COPY

STATE OF NEVADA  
DIVISION OF WATER RESOURCES

OFFICE USE ONLY  
Log No. 89252  
Permit No. 066  
Basin

PRINT OR TYPE ONLY  
DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 46052

1. OWNER Gretzell Gold Corp ADDRESS AT WELL LOCATION SAME  
MAILING ADDRESS 40-66 604260  
Goldconda, NY 89414  
2. LOCATION NW 1/4 SE 1/4 Sec. 11 T. 38 N/S R. 42 E Humboldt County  
PERMIT NO. Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other  
4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
5. WELL TYPE  
 Cable  Rotary  RVG  
 Air  Other SEVIC

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>RED BROWN SAND</u>		<u>0</u>	<u>22</u>	<u>22</u>
<u>+ GRAVEL</u>		<u>22</u>	<u>31</u>	<u>9</u>
<u>REDDISH SAND</u>		<u>31</u>	<u>100</u>	<u>69</u>
<u>CONSISTENT REDDISH</u>				
<u>BROWN SAND +</u>				
<u>GRAVEL</u>		<u>100</u>	<u>150</u>	<u>50</u>
<u>SAND + GRAVEL</u>			<u>150</u>	<u>50</u>
<u>LT. TAN</u>				
<u>hit water @</u>		<u>140'</u>		

8. WELL CONSTRUCTION  
Depth Drilled 150 Feet Depth Cased 145 Feet  
HOLE DIAMETER (BIT SIZE)  
From 0 To 145  
Inches Feet Feet Feet  
CASING SCHEDULE  
Size O.D. (Inches) Weight/Ft. (Pounds) Wall Thickness (Inches) From (Feet) To (Feet)  
2" schedule 40 0 95  
Perforations:  
Type perforation factory  
Size perforation .020  
From 145 feet to 95 feet  
Surface Seal:  Yes  No Seal Type:  
Depth of Seal 10'  Neat Cement  
Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
Gravel Packed:  Yes  No  
From 145 feet to 93 feet

Date started 4/13/03, 19.....  
Date completed 4/17/03, 19.....

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			

9. WATER LEVEL  
Static water level 128' feet below land surface  
Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
Water temperature \_\_\_\_\_ °F Quality \_\_\_\_\_  
10. DRILLER'S CERTIFICATION  
This well was drilled under my supervision and the report is true to the best of my knowledge.  
Name Boart Longyear Contractor  
Address Box 1000 Dayton, NV 89403 Contractor  
Nevada contractor's license number issued by the State Contractor's Board \_\_\_\_\_  
Nevada driller's license number issued by the Division of Water Resources, the on-site driller M-5198  
Signed Wab [Signature]  
By driller performing actual drilling on site or contractor  
Date 4/26/03