BDI Job #: 41292

WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 89257
Permit No.
Basin 105

NOTICE OF INTENT NO. 22728

1. OWNER Douglas County Sewer Improvement Dist.
MAILING ADDRESS P.O. Box 578
Zephyr Cove, NV 89448

ADDRESS AT WELL LOCATION 2120 Stockyard Rd.
Minden, NV

2. LOCATION SW ¼ SE ¼ Sec. 18 T. 13 N/S R. 21 E. MDB & M County

PERMIT NO. D0005 (Issued by Water Resources) 23-101-68 (Parcel No.) 23-010-68 (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☒ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☒ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
MW 21				
PERFORATE CASING 1/4"x1"x16 row/FT Between 50-63				
TREMIE GROUT 0-209 CEMENT GROUT				
REMOVE upper 5' of CASING, MUSHROOM CAP & BACKFILL W/ NATIVE SOIL				
Correct parcel # is 23-010-68 according to Douglas Co Assessor info				

Correct parcel # is 23-010-68 according to Douglas Co. Assessor info

RECEIVED 05 JAN 30 AM 10:56 STATE ENGINEERS OFFICE

Date started 7/17/02, 19
Date completed 7/19/02, 19

7. WELL TEST DATA

TEST METHOD: ☐ Bailer ☒ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
10.3		1.15

8. WELL CONSTRUCTION
Depth Drilled 209 Feet Depth Cased 209 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
10-3/4 Inches	-0- Feet	50 Feet
6-5/8 Inches	50 Feet	209 Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
10-3/4		.250	-0-	50
6-5/8		.250	-0-	188
5		.250	204	209

Perforations:
Type perforation Screen
Size perforation .020
From 183 feet to 204 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50'
Placement Method: ☐ Pumped ☐ Poured

Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☐ Yes ☒ No
From feet to feet

9. WATER LEVEL
Static water level 63.2 feet below land surface
Artesian flow no G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Gene S. Golar for Beylik Drilling (Contractor)
Address 555 S. Harbor Blvd. (Contractor)
La Habra, CA 90631-6124

Nevada contractor's license number issued by the State Contractor's Board 0007055A

Nevada driller's license number issued by the Division of Water Resources, the on-site driller M-2174

Signed Gene Golar
By driller performing actual drilling on site or contractor

Date 8-6-02

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627