

Job #: 41292

WHITE-DIVISION OF WATER RESOURCES  
CANARY-CLIENT'S COPY  
PINK-WELL DRILLER'S COPY

STATE OF NEVADA  
DIVISION OF WATER RESOURCES

OFFICE USE ONLY  
Log No. 89259  
Permit No. \_\_\_\_\_  
Basin 105

PRINT OR TYPE ONLY  
DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 22726  
2120 STOCKYARD RD

1. OWNER Douglas Co Sewer Imp Dist ADDRESS AT WELL LOCATION Minden, NV  
MAILING ADDRESS P.O. Box 578  
Zephyr Cove, NV 89448  
2. LOCATION SW 1/4 SE 1/4 Sec. 18 T 13 N/S R. 21 E MDB & M County  
PERMIT NO. D0005 23-010-68 Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_  
4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>MWD 19</u>				
<u>PERFORATE CASING 74'</u>				
<u>1/4" x 1" x 16/FT</u>				
<u>BETWEEN 50-74'</u>				
<u>TREMIE GROUT</u>				
<u>0-178' NEAT CEMENT</u>				
<u>REMOVE UPPER 5'</u>				
<u>OF CASING, MUST ROOM</u>				
<u>CAP &amp; BACKFILL W/</u>				
<u>NATIVE SOIL</u>				

8. WELL CONSTRUCTION  
Depth Drilled 189 Feet Depth Cased 189 Feet  
HOLE DIAMETER (BIT SIZE)  
From To  
10-3/4 Inches -0- Feet 50 Feet  
6-5/8 Inches Feet 189 Feet  
Inches Feet Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>10-3/4</u>		<u>.250</u>	<u>-0-</u>	<u>50</u>
<u>6-5/8</u>		<u>.250</u>	<u>50</u>	<u>167</u>
<u>5</u>		<u>.250</u>	<u>184</u>	<u>189</u>

Perforations:  
Type perforation Screen  
Size perforation .020  
From 167 feet to 184 feet  
From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
Depth of Seal 50'  Neat Cement  
Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
Gravel Packed:  Yes  No  
From \_\_\_\_\_ feet to \_\_\_\_\_ feet

9. WATER LEVEL  
Static water level 76.8 feet below land surface  
Artesian flow no G.P.M. \_\_\_\_\_ P.S.I. \_\_\_\_\_  
Water temperature \_\_\_\_\_ °F Quality \_\_\_\_\_

Date started 7/17/02 19\_\_\_\_\_  
Date completed 7/19/02 19\_\_\_\_\_  
7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>8.57</u>		<u>1.5</u>

10. DRILLER'S CERTIFICATION  
This well was drilled under my supervision and the report is true to the best of my knowledge.  
Name Gene S. Golar for Beylik Drilling Contractor  
Address 555 S. Harbor Blvd. Contractor  
La Habra, CA 90631-6124  
Nevada contractor's license number 0007055A  
issued by the State Contractor's Board.  
Nevada driller's license number issued by the m-2174  
Division of Water Resources, the on-site driller.  
Signed Gene Golar  
By driller performing actual drilling on site or contractor  
Date 8-6-02