WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 89268
Permit No.
Basin 212

NOTICE OF INTENT NO. 22030

1. **OWNER** Amerco Real Estate / U-Haul
MAILING ADDRESS 2727 N. Central Avenue, Suite 500
Phoenix AZ 85004

ADDRESS AT WELL LOCATION 5316 Boulder Highway
Las Vegas NV 89122

2. **LOCATION** NE 1/4 SW 1/4 Sec 21 T 21S N/S R 62 E County Clark

PERMIT NO (Issued by Water Resources) — Parcel No. 161-21-301-002 — Subdivision Name

3. **WORK PERFORMED**
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. **PROPOSED USE**
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. **WELL TYPE**
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. **LITHOLOGIC LOG**

Material	Water Strata	From	To	Thickness
Concrete		0	2"	2"
Brown gravelly sand		2"	8.0'	7' 10"
Brown clayey sand		8.0'	16.0'	8.0'
Clayey sand, trace gravel		16.0'	24.0'	8.0'
Sandy clay, trace gravel		24.0'	45.0'	21.0'

Date started January 17, 2003
Date completed January 17, 2003

7. **WELL TEST DATA**
TEST METHOD ☐ Bailer ☐ Pumped ☐ Air Lift

	G.P.M	Draw Down (Feet Below Static)	Time (Hours)

8. **WELL CONSTRTUCTION**
Depth Drilled 45 Feet Depth Cased 45 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
6 Inches	0 Feet	45 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2.375		0.308	0	45

Perforations:
Type perforation Factory slot PVC
Size perforation 0.020
From 15 feet to 45 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 5
Placement Method ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout
Gravel Packed: ☒ Yes ☐ No
From 12 feet to 45 feet

9. **WATER LEVEL**
Static water level 27 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. **DRILLER'S CERTIFICATE**
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Converse Consultants (Contractor)
Address 731 Pilot Road, Suite H, Las Vegas NV 89119 (Contractor)
Nevada contractor's license number
Issued by the State Contractor's Board 48947
Nevada driller's license number issued by the
Division of Water Resources, the on-site driller M 1589
Signed (By driller performing actual drilling on-site or contractor)
Date 5/15/03

(Rev. 3-91) **USE ADDITIONAL SHEETS IF NECESSARY** (0)-627