

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

Log No. 89388
 Permit No. _____
 Basin. 037

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

NOTICE OF INTENT NO. 51105

1. OWNER MONT GOMPREY WATSON HARZA ADDRESS AT WELL LOCATION 10 TINTO MINE
STEAMBOAT SPRINGS CO. 80477 2.5 MILE S.E. OF MOUNTAIN CITY, NV.

2. LOCATION NW 1/4 NW 1/4 Sec 11 T. 45 R. 53 E. ELKO County
 PERMIT NO. MO-1041 Issued by Water Resources Parcel No. _____ Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. PZ 13 LITHOLOGIC LOG

| Material | Water Strata | From | To | Thick-ness |
|---------------------------------|--------------|------------|------------|------------|
| <u>ALLUVIUM</u> | | <u>0</u> | <u>15</u> | <u>15'</u> |
| <u>SILTSTONE</u> | | <u>15'</u> | <u>38'</u> | <u>23'</u> |
| <u>1" STEEL CASING LOCK CAP</u> | | <u>73</u> | <u>2</u> | <u>5</u> |
| <u>4" D BEN CHIPS</u> | | <u>2'</u> | <u>23'</u> | <u>21'</u> |
| <u>SAND</u> | | <u>23'</u> | <u>38'</u> | <u>15'</u> |

8. WELL CONSTRUCTION
 Depth Drilled 38' Feet Depth Cased 34' Feet
 HOLE DIAMETER (BIT SIZE)
 From 6" Inches To 35' Feet
478" Inches 35' Feet 38' Feet
 CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|--------------------|---------------------|-------------------------|-------------|------------|
| <u>2"</u> | <u>BLANK</u> | <u>SCH 80</u> | <u>73'</u> | <u>24'</u> |

 Perforations:
 Type perforation HORIZONTAL
 Size perforation 1070
 From _____ feet to _____ feet
 From 24' feet to 34' feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 Surface Seal: Yes No Seal Type:
 Depth of Seal 2' Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 23' feet to 38' feet

9. WATER LEVEL
 Static water level 31' 6" feet below land surface
 Artesian flow N/A G.P.M. N/A P.S.I.
 Water temperature N/A °F Quality N/A

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name EKLUND DRILLING CO. Contractor
 Address 675 P.O. B 2748 Contractor
ELKO NV. 89803
 Nevada contractor's license number issued by the State Contractor's Board 0030823
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1698
 Signed Mary Joyce Harris
 By Driller performing actual drilling on site or contractor
 Date 11/27/02

RECEIVED
 02 DEC -2 PM 1:02
 STATE ENGINEERS OFFICE

PZ 13

Date started 10-9 2002
 Date completed 10-10 2002

7. WELL TEST DATA N/A

| TEST METHOD: | G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|---|--------|-------------------------------|--------------|
| <input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift | | | |