WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 89407
Permit No.
Basin Ø91

NOTICE OF INTENT NO. 42231

1. OWNER Robert Quillici
MAILING ADDRESS P.O. Box 2
Verdi, NV 89439

ADDRESS AT WELL LOCATION 2515 Quilici Ranch Road,
Verdi, NV.

2. LOCATION NE 1/4 NE 1/4 Sec 30 T 19 N/S R 18 E Washoe County
PERMIT NO. Issued by Water Resources
038-260-10 Parcel No.
Subdivision Name

3. WORK PERFORMED
[ ] New Well [ ] Replace [ ] Recondition
[ ] Deepen [X] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [ ] Rotary [ ] RVC
[ ] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Measured static water level at 27.7'. Measured depth of well at 96.9'. Well had 10" casing to 22' and 8" casing from 22' to 96'. Perforated 10" casing with 4 rows per foot and 8" casing with 4 rows per foot using Mills Knife. Installed 94' of 2" tremme pipe and pumped in approximately 3 yards of neat cement. Well volume should have required 1.f yards.				

Date started 10/30/2002, 19__
Date completed 11/01/2002, 19__

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [ ] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 100 Feet Depth Cased 96 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
Inches	Feet	Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
10		.375	+1	22'
8		.250	22	96

Perforations:
Type perforation Mills Knife
Size perforation
From 0 feet to 78 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 96'
Placement Method: [X] Pumped [ ] Poured
Seal Type: [X] Neat Cement [ ] Cement Grout [ ] Concrete Grout

Gravel Packed: [ ] Yes [X] No
From feet to feet

9. WATER LEVEL
Static water level 27.7' feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Carson Pump
Contractor
Address P.O. Box 20159
Contractor
Carson City, NV. 89512

Nevada contractor's license number issued by the State Contractor's Board 39920

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1482

Signed Daniel Tramye
By driller performing actual drilling on-site or contractor

Date 11/04/2002

USE ADDITIONAL SHEETS IF NECESSARY